

72702

Northway Well and Pump Co.

4895 8th Avenue
 Marion, Iowa 52302
 319-377-6339
 1-800-747-6339

100 North 6th Street
 Waukee, Iowa 50263
 515-987-4575
 1-800-747-4575

WELL TEST DATA REPORT

Customer Lake Panorama City Panora, Iowa
 Location 200' S.W. of Treatment Plant Well No. New Jordan
 Size Casing 10" Total Depth 2450' Construction Jordan
 Make Pump Crown Model No. 8L-600 No. of Stages 5
 Diameter 8" Total Setting 600' Air Line Length 600'
 Meter Used 6" Propeller Static Level 402'

DATE	TIME	GPM	P.L.	D.D.	S.C.	PSI	Water Description
10/05/2010	7:45am	565	402'				
	7:46	565	448'	46'	12.28		Clear
	7:47	565	450'	48'	11.77		
	7:48	565	451'	49'	11.53		
	7:49	565	452'	50'	11.30		
	7:50	565	453'	51'	11.08		
	7:55	565	455'	53'	10.66		
	8:00	565	457'	55'	10.27		
	8:05	565	459'	57'	9.91		
	8:10	565	460'	58'	9.74		
	8:15	565	461'	59'	9.57		
	8:30	565	462'	60'	9.41		
	8:45	565	463'	61'	9.26		
	9:00	565	463'	61'	9.26		
	9:15	565	463'	61'	9.26		
	9:30	565	463'	61'	9.26		
	9:45	565	463'	61'	9.26		
	10:00	565	463'	61'	9.26		
	11:00	565	463'	61'	9.26		
	12:00	565	463'	61'	9.26		
	1:00pm	565	463'	61'	9.26		
	2:00	565	463'	61'	9.26		
	3:00	565	463'	61'	9.26		
Recovery	3:05		414'				
	3:10		412'				
	3:15		410'				
	3:20		408'				
	3:25		407'				Through 5:00 well
	3:30		406'				Stayed at 406'