HOEG & AMES, Inc. Survey Copy LINCOLN, IOWA

Sheet No. 1

WELL PRODUCTION TEST DATA SHEET

Job OSSIAN #2 WELL Date Tested FEB 1-1966

Location OSSIAN IOWA Tested by HOEG & AMES INC

Diameter of Well _____ Pump Used TURBINE

Depth of Well 1018 Driver GASOLINE

Length of Airline 450 Col. & Shaft 3½" 496'

Static W. L. 398 Bowls 7"

Orifice Size STOCK TANK MEASURE Mfgr. F.M.

TIME	ORIFICE READING	GPM	PUMPING LEVEL	STATIC W.L.	DRAW-DOWN	REMARKS
1:10 PM.				398		STARTED PUMP
1:30		210	413		15	WATER DIRTY
2:00		215	415		17	WATER CLEARING
2:30		210	415		17	WATER CLEAR
3:00		210	415		17	VERY FINE SAND
3:30		210	415		17	
4:00		210	415		17	
4:30		210	415		17	
5:00		210	415		17	
5:30		210	415		17	
6:00		210	415		17	
6:30		210	415		17	
7:00		210	415		17	
7:30		210	415		17	NO SAND CHECKED BY
8:30		210	415		17	ERVAL-DALE-WHITEY
9:00		210	415		17	AND RALPH WILTGEN
9:30		210	416		18	

HOEG & AMES, Inc. LINCOLN, IOWA

Sheet No. 1

WELL PRODUCTION TEST DATA SHEET

Job OSSIAN #2 WELL Date Tested FEB-1 & 2 - 1966

Location OSSIAN IOWA Tested by HOEG & AMES INC

Diameter of Well _____ Pump Used TURBINE

Depth of Well 1018 Driver GASOLINE

Length of Airline 450 Col. & Shaft 3½" 496'

Static W. L. 398 Bowls 7"

Orifice Size STOCK TANK METERS Mfgr. F.M.

TIME	ORIFICE READING	GPM	PUMPING LEVEL	STATIC W.L.	DRAW-DOWN	REMARKS
10:00		210	416	398	18	WATER VERY CLEAR
10:30		210	416		18	
11:00		210	416		18	
11:30		210	416		18	
12:00		210	417		19	
12:30		210	417		19	
1:00 A.M		210	417		19	
2:00		210	417		19	NO SAND
2:30		210	418		20	"
3:00		210	418		20	
3:30		210	418		20	
4:00		210	418		20	NO SAND
4:30		210	418		20	
5:00		210	418		20	
5:30		210	418		20	
6:00		210	418		20	

HOEG & AMES, Inc.

LINCOLN, IOWA

Sheet No. 3

WELL PRODUCTION TEST DATA SHEET

Job OSSIAN #2 WELL — Date Tested FEB 1 & 2 - 1966

Location OSSIAN IOWA — Tested by HOEG & AMES INC

Diameter of Well _____ — Pump Used TURBINE

Depth of Well 1018 — Driver GASOLINE

Length of Airline 450 — Col. & Shaft 3½" 426'

Static W. L. 398' — Bowls 7"

Orifice Size STOCK TANK MEASURE — Mfgr. F.M.

TIME	ORIFICE READING	GPM	PUMPING LEVEL	STATIC W.L.	DRAW-DOWN	REMARKS
6:30		210	418	398	20	
7:00		210	418		20	
8:00		210	418		20	NO SAND
8:30		210	418		20	
9:00		210	418		20	
10:00		210	418		20	
11:00		210	418		20	NO SAND
						SHUT PUMP OFF.