

Cards for fattle

DRILLER'S NOTEBOOK

WELL RECORD

Driller Mark - Kirk Latta

Address Latta Well - Pump
Wilton, Iowa 52778

Owner Town of Wilton

Tenant _____

Address Wilton, Iowa

#4 52778

Test Hole w/in
100' of ~~proposed~~ well site.

RETURN TO

IOWA GEOLOGICAL SURVEY

IOWA CITY, IOWA

Send Copy of Log to Driller and
Ralph Russell, Howard Green & Co.
Box 9009, Cedar Rapids, Iowa 52409

25940

WELL RECORD

Well is located $\frac{1}{4}$ miles $\begin{matrix} N \\ E \\ S \\ W \end{matrix}$ and $\frac{1}{4}$ miles S from $\begin{matrix} N \\ E \\ W \end{matrix}$

Wilton in Muscatine,
(Nearest Town) (County)

in the SW $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 1 T. 78N R. 2W

Owner City of Wilton (Option) Well No. Test Well

Postoffice address Wilton 52728

Contractor Latta Well & Pump

Address Wilton Ia

Driller Deane Latta

Test Well begun 7-10, 1980;

completed 7-10, 1980

Rig used—Cable, Rotary, Jet, or

Depth of well 203
(Feet)

Size of hole (note total amount of each size) 3 $\frac{1}{4}$

203

Main water supply at 225-193
(Feet below surface)

Final water head 6'
(Feet above or below surface)

Is well pumped? no

Yield —
(Gallons per minute)

Water level when pumping —

Position of well valley
(Upland, valley, side hill, etc.)

11

SAMPLE NO.	DEPTH		THICKNESS
	From	To	
1	0	5	5'
2	5	10	
3	10	15	
	15	20	
	20	25	
	25	30	
	30	35	
	35	40	
	40	45	
	45	50	
	50	55	
	55	60	
	60	65	
	65	70	
	70	75	
	75	80	
	80	85	

DESCRIPTION OF BEDS	
KIND OF ROCK, COLOR, HARD OR SOFT, WATER, ETC.	
Black dirt red sand	
red coarse sand	
gray " "	
" " "	
(gray finer sand gray med	
gray clay	
"	
"	
"	
peat gray clay	
white clay-sand	
gray clay - sand	
gray clay	
"	
"	
sand (gray)	
"	

SAMPLE NO.	DEPTH		THICKNESS	DESCRIPTION OF BEDS	
	From	To		KIND OF ROCK, COLOR, HARD OR SOFT, WATER, ETC.	
	85	90	5'	Coarse sand lime	
	90	95		pea gravel - lime broken	
	95	100		" "	
	100	105		gray clay	
	105	110		" "	
	110	115		" "	
	115	120		" "	
	120	125		" " sand	
	125	130		dirty sand cobbles	
	130	135		" ; " "	
	135	140		" " III	
	140	145		dirty sand -	
	145	150		sand	
	150	155		" "	
	155	160		" "	
	160	165		" "	
	165	170		" "	

SAMPLE NO.	DEPTH		THICKNESS	DESCRIPTION OF BEDS	
	From	To		KIND OF ROCK, COLOR, HARD OR SOFT, WATER, ETC.	
170	170	175	5'		Sand
175	175	180			" "
180	180	185			" "
185	185	190			" "
190	190	195			" clay broken lime
	195	200			gray clay
	200	203			" "
					Bottom of test

Note:

Please send copy of well log to: Driller - Latta Well & Pump and also to:

Mr. Ralph Russell, Engr.

Howard R. Green Co.

P.O. Box 9009 (Glass Road)

Cedar Rapids, Iowa 52409