

WELL LOG

Feet		Feet	Description
0	to	5	Brown clay fill
5	to	8	Black top soil
8	to	10	Gray till
10	to	23	Sandy brown till
23	to	32	Sand to medium gravel with cobbles to boulders
32	to	61	Blue gray clay w/wood
61	to	112	Fine sand to medium gravel w/boulders & wood
112	to	118	Medium gravel to boulders w/broken rock
118	to	119	Till streaks and wood
119	to	147	Fine to coarse gravel w/boulders. A lot of wood
147	to	154	Fine to coarse sand w/boulders, wood
154	to		Bottomed out in gray till
	to		
	to		
	to		
	to		
	to		
	to		
	to		
	to		
	to		
	to		
	to		
	to		
	to		

Well Test Data: Static Level 36.5'; pumping level 55' after 24 hours pumping at 1102 g.p.m.

Length of test 24 hrs. See Well Test Data Sheet Dated 9-1-82

REMARKS:

Boulders from 6" to 12"