Well Information - Rock Wells

#27788

002-198

Layne-Western Company, Inc.

WATER SUPPLY CONTRACTORS

705 SO. DUFF AVE. AMES, IOWA 50010

Phone 515 232-3563

Name of Job MONROE Date 3-

City MONROE State IOWA

Well No: 8 Drillers: LA FONTAINE + EVANS

Well Location: _____ ft. (____) and _____ ft. (____) of the _____ corner of

the _____ ¼ of Section _____, Twp. _____ (____), Range _____ (____) _____ County.

Otherwise located as _____

Work Began: 2-13-81 Work Completed: _____

Casing Record:

Amount	Dia.	Wt. or Thickness	Material				
201	10"	.375	STEEL	with _____	joints from _____	to _____	
_____	_____	_____	_____	with _____	joints from _____	to _____	
_____	_____	_____	_____	with _____	joints from _____	to _____	
_____	_____	_____	_____	with _____	joints from _____	to _____	

Hole Record:

17	inch from	0	to	40
15	inch from	40	to	201
9 7/8	inch from	201	to	312
_____	inch from	_____	to	_____
_____	inch from	_____	to	_____ bottom of hole

Cementing Record: 140 SAX

Well Test Data: Static Level 145'; pumping level 219 after 24 hours pumping at _____ g.p.m

Length of test 24 hrs. See Well Test Data Sheet Dated _____

Remarks: _____

RECEIVED MAR 17 1981 LAYNE-WESTERN CO., INC. AMES, IOWA

SEE OTHER SIDE

LW-34

WELL LOG

#27788

Feet		Feet	Description
0	to	1	SOIL BLACK
1	to	49	CLAY BROWN
49	to	50	LIMESTONE BROWN
50	to	68	CLAY BROWN
68	to	74	CLAY GREY
74	to	90	COAL BLACK
90	to	115	SILTY SHALE GREY
115	to	131	SHALE GREY
131	to	135	SHALE + LIMESTONE GREY HARD
135	to	178	SHALE GREY
178	to	192	SANDSTONE WITH SHALE GREY HARD
192	to	254	SANDSTONE WITH LIMESTONE GREY HARD
254	to	292	SANDSTONE GREY BROWN HARD
292	to	304	SANDSTONE FINE GREY HARD
304	to	311	SANDSTONE + CHERT GREY HARD
311	to	312	TD LIMESTONE GREY VERY HARD