BREMER COUNTY CONSERVATION BOARD 93N-12W

Tripoli, Iowa

Bremer, Frederika, Sec. 7 NE¼NW¼SW¼
June 13-14, 1984

RE: Alcock Park

SHAWVER WELL CO., INC.
P.O. Box 266, Hwy. 18 East
FREDERICKSBURG, IA 50630

#28283

LOG OF WELL

0'	to	2'	Topsoil
2'	to	23'	Sand
23'	to	26'	Limerock
26'	to	30'	Gray limerock
30'	to	32'	Gray shale
32'	to	35'	Gray limerock
35'	to	36'	Brown limerock
36'	to	39'	Gray limerock
39'	to	53'	Limerock
53'	to	57'	Gray limerock
57'	to	60'	Gray and light brown limerock
60'	to	72'	Limerock
72'	to	75'	Gray limerock

The well is cased to 53' with 5" I.D. x .275 wall T&C casing.

OVER

A 10" hole was drilled to 50' and cement grout pumped in the annular space.

The static water level is 10'.

The recommended pump setting is 35'.

BUTCH

#28283