

TO: Mr. Bob Wolf  
2920 Industrial Park Road  
Iowa City, Iowa 52244

RE: Well Log  
#1 Well - East  
Modern Manor Mobile Home Court - Scott Blvd.

<u>Depth</u>	<u>Description of Beds</u>
0' - 1'	- Black dirt
1' - 17'	- Yellow clay
17' - 22'	- Gray clay
22' - 27'	Peat
27' - 45'	Gray clay
45' - 61'	- Gray sand
61' - 81'	- Gray clay
81' - 99'	- Gray clay - streaks of sand
99' - 128'	- Shale - streaks rock - rock dough
128' - 144'	- Black-gray bedrock <i>out as well w/ equipment</i>
144' - 149'	- Gray lime
149' - 162'	- White-brown lime
162' - 229'	- Gray lime
229' - 243' 10"	Brownish white lime
Casing set to 243' 10" - cemented bottom to top	
243' 10" - 292'	Brownish white lime
292' - 324'	- Gray lime
324' - 423'	- Creviced gray lime

*together  
w 229' - 292'*

7" O.D. steel casing  
Static water level - 30'  
Test Pumped 150 gpm @ 180'  
Cemented bottom of casing to top  
DRILLER: LATTA WELL & PUMP  
R. #2  
WILTON, IOWA 52778

cc: M.M.S. Consultants