



Layne-Western Company, Inc.

WATER SUPPLY CONTRACTORS

705 SO. DUFF AVE.

AMES, IOWA 50010

Phone 515 232-3563

Name of Job Amana Refrigeration, Inc. Date May 31, 1990

City Amana State Iowa

Well No: 2 Drillers: Floyd Chilchut

Well Location: _____ ft. (____) and _____ ft. (____) of the _____ corner

the 1/4 of Section _____, Twp. _____ (____), Range _____ (____) _____ Coun

Otherwise located as west edge of parking lot, west of plant

Work Began: 05/02/90 Work Completed: 05/31/90

Casing Record:

Amount	Dia.	Wt. or Thickness	Material		
<u>62'</u>	<u>16"</u>	<u>.375</u>	<u>steel with welded</u>	joints from <u>+2</u>	to <u>60'</u>
<u>84.45</u>	<u>12"</u>	<u>.375</u>	<u>steel with welded</u>	joints from <u>+2</u>	to <u>82.45</u>
<u>227.13</u>	<u>12"</u>	<u>.375</u>	<u>steel with welded</u>	joints from <u>82.45</u>	to <u>309.58</u>
				with _____ joints from _____	to _____

Hole Record:

<u>20"</u>	inch from <u>0</u>	to <u>60</u>
<u>15"</u>	inch from <u>60</u>	to <u>310</u>
<u>10"</u>	inch from <u>310</u>	to <u>550</u>
	inch from _____	to _____
	inch from _____	to _____ bottom of hole

Cementing Record: 16" casing cemented in from 0' to 60'

Well Test Data: Static Level 2; pumping level 223 after 4 hours pumping at 513 g.

Length of test 2 hrs. See Well Test Data Sheet Dated _____

Remarks: will acidize on 06/08/90 and perform 24 hour test following acid treatment

SEE OTHER SIDE

