THORPE WELL COMPANY

2340 SIXTH AVENUE
DES MOINES, IOWA

THIS RECORD IS MICROFILMED

Drilled for City at Cedar Falls, Iowa

By the College

Well is located ____ miles N-E-S-W and ____ miles N-E-S-W from ____

in the ____ ¼ ____ ¼ Section ____ Township ____ Range ____

Drilling started 2- 19 61 Completed 5-5 19 61

Well No. 2 Kind of Well Drilled Depth 145' Size hole started ____ in

Finish 23" G. P. M. 2000 Static Head 30'-6" Pumping level from surface 35 1/2

Water was first encountered at 95' in ____ Approx. Amt. ____ Temp. 54°

Remarks There is cement between 24" and 30" and the curbs are cemented in so they couldn't be pulled

(GIVE DETAILS OF PERFORATED PIPE AND SEALS)

RECORD OF PERMANENT PIPE					TEMPORARY PIPE	
SIZE PIPE	AMOUNT OF PIPE	DEPTH TO BOTTOM OF PIPE	DEPTH TO TOP OF PIPE	MAKE OF PIPE	SIZE PIPE	AMOUNT
52" curb	12'	18'				
36" curb	18'	36'				
34" curb	6'	18'				
60" curb	6'	6'				
30"	63'	61'	2' above ground	welded pipe		
24"	94'	92'	2' abo ve ground			
20"	-95'-9"	93'	+ 2'-9"			

Driller ____ From Surface to ____ feet

Driller Cecil Allen From ____ feet to ____ feet

Driller ____ From ____ feet to ____ feet

AMOUNT IN FEET	KIND OF SOIL OR FORMATION (BE SPECIFIC)	TOTAL DEPTH FEET
3	Black dirt	3
17	Sand	20
3	Blue clay	23
7	Sand	30
8	Lime & yellow clay	38
13	Lime - hard	51
43	Lime - brbken yellow clay	94
27	Broken lime - water	121
24	No cuttings - lime broken	145