DETAIL OF WELL CONSTRUCTION
FOR THE
TOWN OF DAWSON, IOWA

FILE

LAYNE-WESTERN CO., INC. - AMES, IOWA — JANUARY 1971

STATIC LEVEL: 13 FT.	CAPACITY: 100 G.P.M.	DRAWDOWN: 3.5 FT.	PUMPING LEVEL: 16.5 FT.

GEOLOGICAL LOG

SANDY TOPSOIL — 3'

FINE TO COARSE BROWN SAND — 12'

COARSE, BROWN SAND AND GRAVEL

GRAY SHALE — 22'

CONSTRUCTION DETAIL

