



AirPort Lake Park

Shawner

WELL COMPANY INC.

WATER WELL DRILLING AND REPAIRING

P.O. BOX 266

DIAL 319-237-5341

FREDERICKSBURG, IOWA 50630

Chickasaw County Conservation Board

LOG OF WELL

0'	to	2'	Topsoil
2'	to	8'	Red Sand
8'	to	100'	Brown Clay
100'	to	140'	Sand
140'	to	145'	Clay
145'	to	200'	Limerock

The well is cased to 150 feet and 4-inches with 5-inch Inside-Diameter casing and is equipped with a 5-inch forged steel drive shoe.

A 10-inch hole was drilled and cement grout was placed in annular space between the 10-inch hole and the 5-inch casing. Total depth grouted was 100 feet.

Static water level is 50 feet.

The recommended pump setting is 120 feet.