CITY OF MASSENA, IOWA
WELLS 3 & 4

79-1 79-2

AUGUST / SEPTEMBER 1979

LAYNE-WESTERN CO., INC. - AMES, IOWA

WELL NO. 3	STATIC: 10.6'	CAPACITY: 50 GPM	DRAWDOWN: 15.90 FT.	PUMPING LEVEL: 26.50'
WELL NO. 4	STATIC: 7.0'	CAPACITY: 30 GPM	DRAWDOWN: 17.0 FT.	PUMPING LEVEL: 24.0'

Info Wells 3+4

GEOLOGICAL LOG

WELL NO. 3	WELL NO. 4
	ORIGINAL SURFACE
	BLACK SILT CLAY
	4'
BLACK SILT CLAY	
	SOFT GRAY & BROWN CLAY
15'	
LT. BLUE CLAY	19'
	LT. BLUE CLAY & FINE SAND
23'	23'
	COARSE GRAY SAND & GRAVEL WITH CLAY
	26'
	BLUE CLAY
GRAY COARSE SAND & GRAVEL, BOULDERS AND COBBLES	28'
	COARSE GRAY SAND & GRAVEL
	35'
36'	BLUE GRAY CLAY
38' LT. GRAY CLAY	38'

CONSTRUCTION LOG

