WELL NO. 3

Owner: City of Wadena, Iowa

Date Drilled: August 4, 1977

Well Log:

0' to 11' Topsoil & Sand
11' to 63' Limerock
63' to 65' Shale

Comments:

Cased to 36' with 7" O.D. casing equipped with 7" drive shoe.

Static Water Level (SWL) 30'.

Pump Setting 50'.