REVELLE'S 6TH & 7TH ADDITIONS

Well drilled 5/20/72 by: Winslow Drilling Co., Maysville, Ia., 319-391-~~5470.~~ 5740

Location: Back of Lot #37 in 6th Addition.

Water Lines and Tank: Installed by, Morgan Water Co. (no longer in business).

Well: Drilled 561 ft. deep.

Seven inch casing: 412 ft. deep.

Static Water Level: 200 ft. deep; 50 gal. per min. 12/1993 Changed 216

WELL DRILLER'S LOG

put in 12-01-93 SWL 216 @ 50 gpm

0' - 25'	yellow clay
25' - 45'	gray clay
45' - 58'	yellow clay
58' - 75'	sandy yellow clay
75' - 83'	yellow clay
83' - 95'	gray shale
95' - 100'	coal
100' - 115'	gray shale with some sandstone
115' - 130'	gray shale
130' - 140'	rock with some shale
140' - 278'	rock
278' - 283'	rock with a little gray shale
283' - 320'	brown rock
320' - 418'	Silurian white
418' - 561'	gray Silurian