WELL REPORT: H.W.H. Corporation (Paul Hanser) R. R. #1, Moscow, Iowa 52760
SW¼, SW¼ Section 17, T79N, R 2W, Rochester Township

160' 6" PVC Well w/Class 200 casing
Casing set 19' 4"
Test pump 100 gpm @ 100'
Static water level 11'
Set pump 140' [redacted]
Well chlorined
[redacted]

WELL LOG:

Black dirt o' to 8'
Brown clay 8' to 17'
Brown lime 17' to 39'
White dough lime - gray bpown lime 39' to 154'
From 154' to 160' switched to air and have no samplings

Water from silurian