


Site identification
 Property Owner Rick Freese Well Number 1
 Address _____
 Tenant _____
 Well Depth 130 ft Date completed 3/16/2000

Drill method rotary auger cable other _____
Hole size
11 inch from 0 ft to 20 ft hole size continued 6 inch from 87 ft to 130 ft
8 1/2 inch from 20 ft to 87 ft _____ inch from _____ ft to _____ ft

Location County Linn
 _____ mi. ^N and _____ mi. ^E of intersection of _____ and _____
NW 1/4 of the SE 1/4 of the NE 1/4 of Sec 29 TWP 84 RNG 8 ^E _W
 Show exact location of well in section grid with a dot (•). Sketch map of well location on property.

 upland hillside valley Elevation (if known) _____

Record all depth measurements from ground level (GL). Use (+) for above GL measurements.
Casing Drive shoe (yes/no) _____ Pitless adapter (yes/no) _____

Size (ID/OD)	Type / Wt	Depth top	Depth bottom	Amount (length)
6"	1250	+1	87	88
5"	Sch40	70	130	60

Perforated or slotted casing? (yes/no) _____
 Perforated / slotted from 90 ft to 130 ft
 Perforated / slotted from _____ ft to _____ ft

Casing grouted? (yes/no) _____ Placement method _____

Type	Depth Top	Depth bottom	Amount (vol/wt)
Benseal	0	50	4 bags

Formation log

From	To	Color	Hardness	Formation description
0	76	Br		Sand
76	79	Br		Gravel
79	87	Br		Rock
87	95	Gray	Shale	Gray Shale
95	109	Tan	limestone	Tan limestone
109	110	Br	Shale	Br Shale
110	121	Br	limestone	Br limestone
121	122	Pr Br	Shale	Pr Br Shale
122	130	Br	limestone	Br limestone

use additional sheets as needed

Well screen? (yes/no) _____

Diameter	Slot size	Depth Top	Depth Bottom	Length	Material
	0. _____				
	0. _____				

 Bottom capped (yes/no) _____ with _____
 Seals / Packers (yes/no) _____ kind _____ depth _____ ft
 Gravel packed (yes/no) _____ from _____ ft to _____ ft
 type _____ amount _____

Well developed? (yes/no)
 Explain air lift
 (pumped, airlifted, bailed) for _____ hrs at 40 GPM.

Pump installed? (yes/no) _____ Date _____ / _____ / _____
 Installer's name _____
 Type of pump _____ Depth to intake _____ ft
 Pump diameter _____ Rated capacity _____ GPM

Water information Aquifer: sand / gravel limestone sandstone
 Main water-supply zone from 100 ft to 130 ft seepage well
 Static water level 116 ft (below / above) GL; tape airline E-line estimate
 Pumping water level 122 ft below GL; tape airline E-line estimate
 At yield of 40 GPM; orifice volumetric estimate
 Measurements taken at _____ : _____ (AM / PM) Date 3/16/2000

Remarks (including depth of lost drilling fluids, materials, or tools)

Water quality test? (yes/no) Date tested 3/16/2000
 Tested by _____

Well use
 Domestic Municipal Commercial
 Livestock Public supply Monitoring
 Test well Irrigation Other _____ (explain)

Contractor Freese Well Drilling
 Address 756 E Post CT SE CR
 Driller Freese Certification no. 40153