Northway Well and Pump Co.

4895 8th Avenue
Marion, Iowa 52302
Phone 319/377-6339

Drilled for City Water Department of West Des Moines, Iowa

Well is located ____ miles N-E-S-W and ____ miles N-E-S-W from ____

in the ____ ¼ ____ ¼ Section ____ Township ____ Range ____

Drilling started January 16 19 95 Completed January 17 19 95

Well No. 15 Kind of Well Gravel Pack Depth 35' Size hole started 52" in

Finish 52" G. P. M. 540 Static Head 11'5" Pumping level from surface 24'5½"

Water was first encountered at ____ in ____ Approx. Amt. ____ Temp. ____

Remarks ____

(GIVE DETAILS OF PERFORATED PIPE AND SEALS)

RECORD OF PERMANENT PIPE					TEMPORARY PIPE	
SIZE PIPE	AMOUNT OF PIPE	DEPTH TO BOTTOM OF PIPE	DEPTH TO TOP OF PIPE	MAKE OF PIPE	SIZE PIPE	AMOUNT
20"	10'	34'	24'	Cook S.S.Screen .040 slot		
20"	32'	24'	+8'	.50" wall Black steel		
#1		35'	19'	Northern Gravel		
		19'	10'	Bentonite Seal		
		10'	0'	Cement Grout		

Driller Don Murphy From Surface to 35' feet

Driller ____ From ____ feet to ____ feet

Driller ____ From ____ feet to ____ feet

AMOUNT IN FEET	KIND OF SOIL OR FORMATION (BE SPECIFIC)	TOTAL DEPTH FEET
9'	Brown Clay	9'
26'	Brown to Gray Fine Sand to Coarse Sand	35'
	Gray Clay Bottom	