MID AMERICA DRILLING CORP.
HENRY WELL COMPANY
P.O. BOX 399
202 N MAIN
OAKLAND, IOWA 51560

PH: 712-482-6911 FAX: 712-482-3366

FAX

Well No. 7
Log & Test Pumping

TO: Snyder & Associates

ATTENTION: Harold

FROM: Gayla/Paul

DATE: 05/20/02

FAX NUMBER: 243-6507

PHONE NUMBER:243-6505

TOTAL PAGES (INCLUDING COVER SHEET): 3

REFERENCE: SHELBY LOGS

May 20, 2002

City of Shelby
Well log

0 - 4	top soil
4 - 16	tan clay
16 - 31	blue clay
31 - 46	blue clay w/ sand lenses
46 - 50	gray clay
50 - 52	medium gravel
52 - 55	gray clay
55 - 58	medium gravel
58 - 60	gray clay
60 - 64	medium gravel
64 - 70	gray clay

Pump test
Stateic water level - 8'

Water Level	Time	GPM
16'5"	6:07	72
23'0"	6:08	72
28'5"	6:09	72
33'0"	6:10	72
37'7"	6:11	72
52'0"	6:16	72
57'6"	6:21	60
58'6"	6:26	60
58'6"	6:31	36
58'6"	6:36	36
58'6"	6:41	36
58'6"	6:46	36
58'6"	6:51	36
58'6"	6:56	36
58'6"	7:01	36

Shelby page 2

Water Level	Time	GPM
58'6"	7:06	36
58'6"	7:11	36
58'6"	7:16	33
58'6"	7:36	33
58'6"	7:56	33
58'6"	8:16	33
58'6"	8:46	33
58'6"	9:16	33
58'6"	9:46	33
58'6"	10:46	33
58'6"	11:46	33
58'6"	12:46	33
58'6"	1:46	33
58'6"	2:46	33
58'6"	3:46	33
58'6"	4:46	33
58'6"	5:46	33
58'6"	6:46	33
58'6"	7:46	33
58'6"	8:46	33
58'6"	9:46	33
58'6"	10:46	33
58'6"	11:46	33
58'6"	12:46	33
58'6"	1:46	33
58'6"	2:46	33
58'6"	3:46	33
58'6"	4:46	33