


Site identification
 Property Owner Brad Skoff Other ID _____
 Address 27918 Territorial Rd LeClaire IA
 Tenant _____ 52743
 Well Depth 264 ft Date completed 5/3/07

Location County Scott
1/8 mi. W and 1/2 mi. E of intersection of IA 67 and Territorial Rd
1/4 of the SE 1/4 of the SE 1/4 of Sec 27 TWP 79N RANG 5 E Lot 5

GPS Coordinates (NAD83 datum only) decimal degrees:
 _____ N. Latitude _____ W. Longitude.



upland hillside valley level surface Elevation (if known) _____

Formation log

From	To	Color	Hardness	Formation description
0	2	brn	S	top soil
2	11	y/w	S	oxidized till
11	19	RED	M	decomposed Rock/clay
19	84	y/w	H	limestone
84	173	wht	H	limestone
173	231	beige	H	limestone
231	264	brn	H	limestone

use additional sheets as needed

Remarks (including depth of lost drilling fluids, materials, or tools)

Well use

Domestic
 Livestock
 Test well

Heat pump
 Municipal
 Public supply
 Irrigation

Commercial
 Monitoring
 Other _____

Drill method Rotary auger cable other _____

Hole size
9 7/8 inch from 0 ft to 118 ft
5 7/8 inch from 118 ft to 264 ft

hole size continued
 _____ inch from _____ ft to _____ ft
 _____ inch from _____ ft to _____ ft

Record all depth measurements from ground level (GL). Use (+) for above GL measurements.

Casing Drive shoe (yes/no) _____ Pileless adapter (yes/no) _____

Size (ID/OD)	Type/Wt	Depth top	Depth bottom	Amount (length)
6" 1 1/2	SDR21	+1.5	118	120

Perforated or slotted casing? (yes/no)

Perforated / slotted from _____ ft to _____ ft
 Perforated / slotted from _____ ft to _____ ft

Casing grouted? (yes/no) Placement method pumped/premix

Type	Depth top	Depth bottom	Amount (vol/wt)
bone / POLY	0	118	12 batches

Well screen? (yes/no)

Diameter	Slot size	Depth top	Depth bottom	Length	Material
0	0				

Bottom capped (yes/no) with _____
 Seals / Packers (yes/no) kind shale boot depth 117 ft
 Gravel packed (yes/no) from _____ ft to _____ ft
 type _____ amount _____

Well developed? (yes/no)

Explain _____
 (pumped, aerated, bailed) for 1.5 hrs at 35 GPM

Pump installed? (yes/no) _____ Date 1/1/
 Installer's name _____
 Type of pump _____ Depth to intake _____ ft
 Pump diameter _____ Rated capacity _____ GPM

Water information Aquifer: sand / gravel limestone sandstone
 Main water-supply zone from 174 ft to 238 ft seepage well
 Static water level 98 ft (below/above) GL; tape airline E-line estimate
 Pumping water level 160 ft below GL; tape airline E-line estimate
 At yield of 15 GPM; orifice volumetric estimate for .5 hours
 Measurements taken at 3:30 (AM/PM) Date 5/3/07

Water quality test? (yes/no) Date tested 1/1/
 Tested by _____

Contractor High Performance Drilling
 Address Coal Valley, IL
 Driller Todd R. List Certification no. 3715