
National water well Association
MEMBER

HOEG & AMES, Inc.

WELL CONTRACTORS WELL SUPPLIES

* * *

LINCOLN, IOWA



1957

LOG OF WELL

TOWN OF STRAWBERR POINT, IOWA, TEST WELL NO. 4 (Well # 4 South)

Total depth of well - 245 ft.

Static water level - 95 ft. 8 in.

24 ft. 4 in. drawdown, pumping at 252 gal. per min.

101 ft. 3 in. of 6 in. pipe

Formation:

Black dirt	0-2 Ft.
Yellow sandy clay	2-15 Ft.
Blue clay	15-45 Ft.
Blue clay with sand and gravel	45-90 Ft.
Fine sand	90-96 Ft.
Rock with yellow bands	96-100 Ft.
Light brown rock	100-145 Ft.
Gray rock	145-170 Ft.
Light brown rock	170-215 Ft.
Dark gray	215-230 Ft.
Gray with gray shale	230-240 Ft.
Light blue shale	240-245 Ft.

Well # 4 (South)