


920.326.5193 Randolph  
 608.251.4318 Madison  
 800.321.5193  
 920.326.5209 Fax



PO Box 150  
 Randolph, WI 53956

Job Name	<u>City of Marion</u>	Screened	<u>NA</u>
Address	<u>2351 31st St</u>	Casing Size	<u>12"</u>
Well No.	<u>8</u>	Casing Depth	<u>152</u>
Total Dpth of Well	<u>520</u>	Casing above grd	<u>1.5</u>
Test Pumping:	Date Started <u>24-Jun</u>	Date Completed	<u>25-Jun</u>
Static Wtr Level	<u>75</u> Electric <input type="checkbox"/> Airline <input checked="" type="checkbox"/>	Measured by:	<u>Duane Vorwald</u>
Type of Pump	<u>Submersible</u>	Airline Depth	<u>147</u>
Pump HP	<u>40</u>	Pump Intake at	<u>147</u>

**Final Test Pumping Data**

Notes	Date	Time	Air Gauge Reading	Depth to Water	GPM
	24-Jun	2:15 PM	32.5	75.075	0
Pump test started	24-Jun	2:25 PM	24	91.56	500
	24-Jun	2:30 PM	24	91.56	500
	24-Jun	2:35 PM	24	91.56	500
	24-Jun	2:40 PM	24	91.56	500
	24-Jun	2:50 PM	24	91.56	500
	24-Jun	3:00 PM	23	93.87	500
	24-Jun	3:10 PM	23	93.87	500
	24-Jun	3:20 PM	23	93.87	500
	24-Jun	3:30 PM	23	93.87	500
	24-Jun	3:40 PM	22	96.18	500
	24-Jun	3:50 PM	22	96.18	500
	24-Jun	4:00 PM	22	96.18	500
	24-Jun	4:10 PM	22	96.18	500
	24-Jun	4:20 PM	22	96.18	500
	24-Jun	4:30 PM	22	96.18	500
	24-Jun	4:40 PM	22	96.18	500
	24-Jun	5:40 PM	20	100.8	500
	24-Jun	6:40 PM	20	100.8	500
	24-Jun	7:40 PM	20	100.8	500
	24-Jun	8:40 PM	20	100.8	500
	24-Jun	9:40 PM	20	100.8	500
	24-Jun	10:40 PM	19	103.11	500
	24-Jun	11:40 PM	19	103.11	500
	25-Jun	12:40 AM	19	103.11	500
	25-Jun	1:40 AM	18.5	104.265	500
	25-Jun	2:40 AM	18	105.42	500
	25-Jun	3:40 AM	18	105.42	500
	25-Jun	4:40 AM	18	105.42	500

Notes	Date	Time	Air Gauge Reading	Depth to Water	GPM
	25-Jun	5:40 AM	18	105.42	500
	25-Jun	6:40 AM	18	105.42	500
	25-Jun	7:40 AM	18	105.42	500
	25-Jun	8:40 AM	18	105.42	500
	25-Jun	9:40 AM	18	105.42	500
	25-Jun	10:40 AM	17	107.73	500
	25-Jun	11:40 AM	17.5	106.575	500
	25-Jun	12:40 PM	17	107.73	500
Pump wide open	25-Jun	1:40 PM	16	110.04	615
	25-Jun	2:00 PM	16	110.04	615
	25-Jun	2:15 PM	16	110.04	615
	25-Jun	2:30 PM	16	110.04	615
	25-Jun	2:45 PM	16	110.04	615
Pump shut off	25-Jun	3:00 PM	16	110.04	615
	25-Jun	3:05 PM	20	100.8	0
	25-Jun	3:10 PM	22	96.18	0
	25-Jun	3:20 PM	24	91.56	0
	25-Jun	3:30 PM	26	86.94	0
	25-Jun	4:30 PM	28	82.32	0
	25-Jun	7:30 PM	31	75.39	0