w#80327

WELL TEST DATA SHEET

CLIENT: Rinard

WELL: # 4

DATE: 7/28/15

TESTED BY: Rodney

PUMP MODEL: 406550 Centripro

AIRLINE LENGTH: 190'

DIAMETER: 10"

ORIFICE SIZE: 6x2

DEPTH OF WELL: 278.5'

MOTOR: Franklin 230v 1ph

STATIC WATER LEVEL: 124'

GENERATOR USED: Yes No __X__ GN1 GN2

BEGIN HOURS: _____ END HOURS: _____

STEP-RATE TEST

CONSTANT RATE TEST

PRE-TREATMENT

POST –TREATMENT

MEASUREMENT TAKEN FROM THE TOP OF THE WELL CASING WHICH IS __4__ FEET FROM EXISTING GROUND/FLOOR LEVEL.

w#80327

TIME	PIZOM READING	GPM	Air Gauge	Pumping Level	Draw Down	Discharge PSI FEET	TDH	Spec Cap	Sand PPM
8:15	6	37	55	135	9'	76 175.56	310.56	4.11	
8:20	6	37	54	136	10'	76 175.56	311.56	3.7	
8:25	6	37	54	136	10'	76 175.56	311.56	3.7	
8:30	6	37	54	136	10'	76 175.56	311.56	3.7	
8:35	12	52.3	48	142	16'	76 175.56	206.68	3.27	
8:40	12	52.3	48	142	16'	76 175.56	206.68	3.27	
8:45	12	52.3	47	143	17'	76 175.56	206.68	3.08	
8:50	12	52.3	47	143	17'	76 175.56	206.68	3.08	
8:55	14	56.5	46	144	18'	0 0 1	144	3.14	
9:00	14	56.5	46	144	18'	0 0	144	3.14	
9:05	14	56.5	45	145	19'	0 0	145	3.97	
9:10	14	56.5	45	145	19'	0 0	145	3.97	