

Oasis Well & Pump Co.

1332 N. Franklin St
 Manchester, Ia 52057
 563-927-6503
 888-666-6503

WELL TEST DATA REPORT

Customer Lost Beach Resort City Delhi
 Location _____ Well No. _____
 Size Casing 6" Total Depth 143 Construction Rotary
 Make Pump _____ Model No. _____ No. of Stages _____
 Diameter _____ Total Setting 84' Air Line Length 84'
 Meter Used _____ Static Level 110

DATE	TIME	GPM	P.L.	W/L D.D.	S.C.	P.S.I.	TEMP DISCHARGE DESCRIPTION
4-18	10:45	60	84	16			65.3
	10:46	↓	↓	22			
	10:47	↓	↓	22			
	10:48	↓	↓	23			
	10:49	↓	94'	23			
	10:50	↓	↓	24			66
	10:55	↓	↓	25			66.6
	11:00	60	↓	27			67.2
	11:05	↓	↓	28			67.3
	11:10	↓	↓	29			68.4
	11:15	↓	↓	30			68.2
	11:20	↓	↓	31			67.5
	11:25	↓	↓	32			67.7
	11:30	↓	↓	33			67.
	11:35	60	↓	34			66.3
	11:40	↓	↓	36			65.3
	11:45	↓	↓	38			64.6
	12:00	↓	↓	40			63.3
	12:15	↓	↓	43			64.4
	12:30	↓	↓	45			70
	12:45	60	↓	48			71.6
	1:15	↓	↓	49			82
	1:45	↓	↓	53			79.9
	2:15	↓	↓	54			79.1
	2:45	60	↓	57			76.1
	3:00	60	94'	59			76.1

Oasis Well & Pump Co.

1332 N. Franklin St
 Manchester, Ia 52057
 563-927-6503
 888-666-6503

WELL TEST DATA REPORT

Customer Lost Beach Resort City Delhi
 Location _____ Well No. _____
 Size Casing _____ Total Depth 143' Construction _____
 Make Pump _____ Model No. _____ No. of Stages _____
 Diameter _____ Total Setting 84' Air Line Length _____
 Meter Used _____ Static Level 16'

DATE	TIME	GPM	P.L.	W.L. D.D.	S.C.	P.S.I.	TEMP DISCHARGE DESCRIPTION
4-18-17	3:15	60	84'	59			74.7
	3:45			59			74.7
	4:15			58			72.
	4:45			59			74.3
	5:15			59			72.
	5:45			59			68.4
	6:15			58			67
	6:45		84'	58			66.4
	7:15			58			64.8
	7:45			58			65.4
	8:15			58			63
	8:45	60		58			59.3
	9:15			58			59.6
	9:45			58			58
	10:15			58			57.8
	10:45			58			57.1
12 Hour Test	11:15			58			55.8
	11:45			58			54.8
4-19-17	12:15pm			58			54.4
	12:45			58			53.9
	1:15			58			55.6
	1:45			58			54.6
	2:15			58			52.5
	2:45	60	84'	58			50.2

