

**SHAWVER WELL COMPANY, INC.
TEST PUMPING REPORT**

Sears 66

Date: January 30-31, 2018

Test Pump Crew:		Lucas Treangen & Paul Woodhouse			Casing above ground: 30'	
Depth of Well:		250'			Miscellaneous: Readings were taken from the top of the casing. <i>24 Hour Test</i> <i>Start Time: 01/30/18 @ 11:15 AM</i> <i>End Time: 01/31/18 @ 11:15 AM</i> <i>2 Hour Recovery</i>	
Size of Well:		10"				
SWL:		5.72"				
Pump Model:		33GS10				
Pump HP:		1 HP				
Length of Transducer:		99'				
Depth of Pump:		100' - 1 1/4 PVC				
		Sears 66				
Date	Time	GPM	PWL	Temp	Sand	Water/Pumping Details
1/30/2018	11:05 AM	0	5.51	51.38		
1/30/2018	11:06 AM	0	5.51	51.40		
1/30/2018	11:07 AM	0	5.51	51.40		
1/30/2018	11:08 AM	0	5.51	51.39		
1/30/2018	11:09 AM	0	5.50	51.43		
1/30/2018	11:10 AM	0	5.51	51.41		
1/30/2018	11:11 AM	0	5.51	51.42		
1/30/2018	11:12 AM	0	5.51	51.42		
1/30/2018	11:13 AM	0	5.51	51.43		
1/30/2018	11:14 AM	0	5.51	51.45		
1/30/2018	11:15 AM	0	5.72	51.43		
START UP PUMP						
1/30/2018	11:16 AM	25	15.57	51.43		
1/30/2018	11:17 AM	25	24.02	51.56		
1/30/2018	11:18 AM	25	31.79	51.69		
1/30/2018	11:19 AM	25	36.54	51.89		
1/30/2018	11:20 AM	25	39.65	52.02		
1/30/2018	11:21 AM	25	41.70	52.18		
1/30/2018	11:22 AM	25	43.23	52.20		
1/30/2018	11:23 AM	25	44.21	52.28		
1/30/2018	11:24 AM	25	45.02	52.33		
1/30/2018	11:25 AM	25	45.48	52.33		
1/30/2018	11:26 AM	25	45.98	52.25		
1/30/2018	11:27 AM	25	46.27	52.29		
1/30/2018	11:28 AM	25	46.59	52.24		
1/30/2018	11:29 AM	25	46.80	52.11		
1/30/2018	11:30 AM	25	46.93	52.02		Water Cloudy
1/30/2018	11:31 AM	25	47.19	51.94		
1/30/2018	11:32 AM	25	47.32	51.90		
1/30/2018	11:33 AM	25	47.44	51.90		
1/30/2018	11:34 AM	25	47.54	51.82		
1/30/2018	11:35 AM	25	47.67	51.79		
1/30/2018	11:36 AM	25	47.74	51.70		
1/30/2018	11:37 AM	25	47.88	51.68		
1/30/2018	11:38 AM	25	48.01	51.66		
1/30/2018	11:39 AM	25	48.05	51.61		
1/30/2018	11:40 AM	25	48.15	51.58		
1/30/2018	11:41 AM	25	48.22	51.55		
1/30/2018	11:42 AM	25	48.31	51.56		
1/30/2018	11:43 AM	25	48.35	51.55		
1/30/2018	11:44 AM	25	48.42	51.57		

**SHAWVER WELL COMPANY, INC.
TEST PUMPING REPORT**

Sears 66

Date: January 30-31, 2018

Date	Time	GPM	Sears 66			Water/Pumping Details
			PWL	Temp	Sand	
1/30/2018	11:45 AM	25	48.53	51.55		Water Clear
1/30/2018	11:46 AM	25	48.54	51.55		No Sand
1/30/2018	11:47 AM	25	48.55	51.52		
1/30/2018	11:48 AM	25	48.65	51.53		
1/30/2018	11:49 AM	25	48.75	51.53		
1/30/2018	11:50 AM	25	48.78	51.54		
1/30/2018	11:51 AM	25	48.84	51.48		
1/30/2018	11:52 AM	25	48.86	51.53		
1/30/2018	11:53 AM	25	48.92	51.49		
1/30/2018	11:54 AM	25	48.93	51.51		
1/30/2018	11:55 AM	25	49.07	51.51		
1/30/2018	11:56 AM	25	49.02	51.52		
1/30/2018	11:57 AM	25	49.12	51.49		
1/30/2018	11:58 AM	25	49.19	51.51		
1/30/2018	11:59 AM	25	49.23	51.53		
1/30/2018	12:00 PM	25	49.19	51.55		
1/30/2018	12:01 PM	25	49.25	51.50		
1/30/2018	12:02 PM	25	49.26	51.54		
1/30/2018	12:03 PM	25	49.32	51.53		
1/30/2018	12:04 PM	25	49.40	51.50		
1/30/2018	12:05 PM	25	49.34	51.48		
1/30/2018	12:06 PM	25	49.43	51.51		
1/30/2018	12:07 PM	25	49.43	51.50		
1/30/2018	12:08 PM	25	49.47	51.50		
1/30/2018	12:09 PM	25	49.49	51.48		
1/30/2018	12:10 PM	25	49.53	51.50		
1/30/2018	12:11 PM	25	49.57	51.50		
1/30/2018	12:12 PM	25	49.64	51.50		
1/30/2018	12:13 PM	25	49.58	51.49		
1/30/2018	12:14 PM	25	49.69	51.51		
1/30/2018	12:15 PM	25	49.66	51.50		
1/30/2018	12:16 PM	25	49.76	51.50		
1/30/2018	12:17 PM	25	49.71	51.48		
1/30/2018	12:18 PM	25	49.77	51.50		
1/30/2018	12:19 PM	25	49.80	51.45		
1/30/2018	12:20 PM	25	49.83	51.50		
1/30/2018	12:21 PM	25	49.85	51.48		
1/30/2018	12:22 PM	25	49.86	51.52		
1/30/2018	12:23 PM	25	49.89	51.46		
1/30/2018	12:24 PM	25	49.93	51.46		
1/30/2018	12:25 PM	25	49.95	51.49		
1/30/2018	12:26 PM	25	50.00	51.47		
1/30/2018	12:27 PM	25	49.98	51.46		
1/30/2018	12:28 PM	25	50.01	51.42		
1/30/2018	12:29 PM	25	50.03	51.53		
1/30/2018	12:30 PM	25	50.10	51.49		
1/30/2018	12:31 PM	25	50.10	51.48		
1/30/2018	12:32 PM	25	50.10	51.51		
1/30/2018	12:33 PM	25	50.14	51.45		
1/30/2018	12:34 PM	25	50.09	51.48		

**SHAWVER WELL COMPANY, INC.
TEST PUMPING REPORT**

Sears 66

Date: January 30-31, 2018

Date	Time	GPM	Sears 66			Water/Pumping Details
			PWL	Temp	Sand	
1/30/2018	12:35 PM	25	50.13	51.49		
1/30/2018	12:36 PM	25	50.16	51.48		
1/30/2018	12:37 PM	25	50.25	51.51		
1/30/2018	12:38 PM	25	50.24	51.53		
1/30/2018	12:39 PM	25	50.21	51.48		
1/30/2018	12:40 PM	25	50.28	51.47		
1/30/2018	12:41 PM	25	50.28	51.47		
1/30/2018	12:42 PM	25	50.30	51.44		
1/30/2018	12:43 PM	25	50.33	51.49		
1/30/2018	12:44 PM	25	50.33	51.46		
1/30/2018	12:45 PM	25	50.35	51.53		
1/30/2018	12:46 PM	25	50.35	51.50		
1/30/2018	12:47 PM	25	50.41	51.50		
1/30/2018	12:48 PM	25	50.38	51.48		
1/30/2018	12:49 PM	25	50.40	51.51		
1/30/2018	12:50 PM	25	50.39	51.48		
1/30/2018	12:51 PM	25	50.48	51.44		
1/30/2018	12:52 PM	25	50.42	51.49		
1/30/2018	12:53 PM	25	50.51	51.48		
1/30/2018	12:54 PM	25	50.45	51.50		
1/30/2018	12:55 PM	25	50.46	51.51		
1/30/2018	12:56 PM	25	50.52	51.46		
1/30/2018	12:57 PM	25	50.53	51.46		
1/30/2018	12:58 PM	25	50.55	51.46		
1/30/2018	12:59 PM	25	50.56	51.48		
1/30/2018	1:00 PM	25	50.55	51.49		
1/30/2018	1:01 PM	25	50.58	51.49		
1/30/2018	1:02 PM	25	50.55	51.45		
1/30/2018	1:03 PM	25	50.66	51.51		
1/30/2018	1:04 PM	25	50.60	51.50		
1/30/2018	1:05 PM	25	50.63	51.50		
1/30/2018	1:06 PM	25	50.59	51.46		
1/30/2018	1:07 PM	25	50.63	51.49		
1/30/2018	1:08 PM	25	50.58	51.49		
1/30/2018	1:09 PM	25	50.62	51.48		
1/30/2018	1:10 PM	25	50.68	51.50		
1/30/2018	1:11 PM	25	50.63	51.49		
1/30/2018	1:12 PM	25	50.48	51.47		
1/30/2018	1:13 PM	25	50.49	51.48		
1/30/2018	1:14 PM	25	50.41	51.46		
1/30/2018	1:15 PM	25	50.46	51.47		
1/30/2018	1:30 PM	25	50.98	51.49		
1/30/2018	1:45 PM	25	51.18	51.49		
1/30/2018	2:00 PM	25	51.20	51.46		
1/30/2018	2:15 PM	25	51.40	51.49		
1/30/2018	2:30 PM	25	51.49	51.47		
1/30/2018	2:45 PM	25	51.68	51.45		
1/30/2018	3:00 PM	25	51.74	51.45		
1/30/2018	3:15 PM	25	51.80	51.48		
1/30/2018	3:45 PM	25	51.92	51.48		

**SHAWVER WELL COMPANY, INC.
TEST PUMPING REPORT**

Sears 66

Date: January 30-31, 2018

Date	Time	GPM	Sears 66			Water/Pumping Details
			PWL	Temp	Sand	
1/30/2018	4:15 PM	25	52.14	51.49		
1/30/2018	4:45 PM	25	52.26	51.46		
1/30/2018	5:15 PM	25	52.33	51.47		
1/30/2018	6:15 PM	25	52.58	51.49		
1/30/2018	7:15 PM	25	52.76	51.49		
1/30/2018	8:15 PM	25	52.97	51.48		
1/30/2018	9:15 PM	25	53.11	51.49		
1/30/2018	10:15 PM	25	53.21	51.49		
1/30/2018	11:15 PM	25	53.43	51.46		
1/31/2018	12:15 AM	25	53.45	51.49		
1/31/2018	1:15 AM	25	53.52	51.50		
1/31/2018	2:15 AM	25	53.59	51.50		
1/31/2018	3:15 AM	25	53.65	51.46		
1/31/2018	4:15 AM	25	53.79	51.51		
1/31/2018	5:15 AM	25	53.85	51.48		
1/31/2018	6:15 AM	25	53.89	51.50		
1/31/2018	7:15 AM	25	54.02	51.49		
1/31/2018	7:16 AM	25	53.91	51.50		
1/31/2018	7:17 AM	25	54.02	51.52		
1/31/2018	7:18 AM	25	54.01	51.48		
1/31/2018	7:19 AM	25	54.03	51.47		
1/31/2018	7:20 AM	25	54.02	51.50		
1/31/2018	7:21 AM	25	54.04	51.47		
1/31/2018	7:22 AM	25	54.01	51.46		
1/31/2018	7:23 AM	25	54.04	51.46		
1/31/2018	7:24 AM	25	53.94	51.46		
1/31/2018	7:25 AM	25	54.05	51.49		
1/31/2018	7:26 AM	25	54.03	51.51		
1/31/2018	7:27 AM	25	54.00	51.45		
1/31/2018	7:28 AM	25	54.00	51.46		
1/31/2018	7:29 AM	25	54.09	51.50		
1/31/2018	7:30 AM	25	54.03	51.48		
1/31/2018	7:31 AM	25	54.01	51.47		
1/31/2018	7:32 AM	25	54.03	51.46		
1/31/2018	7:33 AM	25	53.98	51.50		
1/31/2018	7:34 AM	25	53.96	51.46		
1/31/2018	7:35 AM	25	54.02	51.47		
1/31/2018	7:36 AM	25	54.06	51.44		
1/31/2018	7:37 AM	25	54.03	51.48		
1/31/2018	7:38 AM	25	54.02	51.50		
1/31/2018	7:39 AM	25	53.98	51.49		
1/31/2018	7:40 AM	25	54.02	51.49		
1/31/2018	7:41 AM	25	53.98	51.49		
1/31/2018	7:42 AM	25	54.06	51.51		
1/31/2018	7:43 AM	25	54.01	51.50		
1/31/2018	7:44 AM	25	53.99	51.46		
1/31/2018	7:45 AM	25	53.93	51.51		
1/31/2018	7:46 AM	25	54.04	51.47		
1/31/2018	7:47 AM	25	54.07	51.49		
1/31/2018	7:48 AM	25	54.11	51.51		

**SHAWVER WELL COMPANY, INC.
TEST PUMPING REPORT**

Sears 66

Date: January 30-31, 2018

Date	Time	GPM	Sears 66			Water/Pumping Details
			PWL	Temp	Sand	
1/31/2018	7:49 AM	25	54.03	51.54		
1/31/2018	7:50 AM	25	54.02	51.51		
1/31/2018	7:51 AM	25	54.11	51.47		
1/31/2018	7:52 AM	25	53.94	51.48		
1/31/2018	7:53 AM	25	54.10	51.49		
1/31/2018	7:54 AM	25	54.01	51.44		
1/31/2018	7:55 AM	25	54.04	51.48		
1/31/2018	7:56 AM	25	54.04	51.51		
1/31/2018	7:57 AM	25	53.97	51.49		
1/31/2018	7:58 AM	25	54.03	51.49		
1/31/2018	7:59 AM	25	54.05	51.46		
1/31/2018	8:00 AM	25	54.09	51.45		
1/31/2018	8:01 AM	25	54.05	51.50		
1/31/2018	8:02 AM	25	53.98	51.47		
1/31/2018	8:03 AM	25	54.07	51.50		
1/31/2018	8:04 AM	25	54.10	51.50		
1/31/2018	8:05 AM	25	54.10	51.48		
1/31/2018	8:06 AM	25	54.08	51.49		
1/31/2018	8:07 AM	25	54.06	51.44		
1/31/2018	8:08 AM	25	54.09	51.48		
1/31/2018	8:09 AM	25	54.09	51.51		
1/31/2018	8:10 AM	25	54.11	51.47		
1/31/2018	8:11 AM	25	54.06	51.46		
1/31/2018	8:12 AM	25	54.06	51.50		
1/31/2018	8:13 AM	25	54.01	51.50		
1/31/2018	8:14 AM	25	54.03	51.50		
1/31/2018	8:15 AM	25	54.10	51.49		
1/31/2018	8:16 AM	25	54.13	51.50		
1/31/2018	8:17 AM	25	54.09	51.49		
1/31/2018	8:18 AM	25	54.03	51.49		
1/31/2018	8:19 AM	25	54.07	51.48		
1/31/2018	8:20 AM	25	54.05	51.46		
1/31/2018	8:21 AM	25	54.03	51.49		
1/31/2018	8:22 AM	25	54.17	51.48		
1/31/2018	8:23 AM	25	54.13	51.47		
1/31/2018	8:24 AM	25	54.01	51.47		
1/31/2018	8:25 AM	25	54.06	51.48		
1/31/2018	8:26 AM	25	54.08	51.52		
1/31/2018	8:27 AM	25	54.06	51.52		
1/31/2018	8:28 AM	25	54.17	51.47		
1/31/2018	8:29 AM	25	54.04	51.46		
1/31/2018	8:30 AM	25	54.09	51.50		
1/31/2018	8:31 AM	25	54.12	51.46		
1/31/2018	8:32 AM	25	54.10	51.47		
1/31/2018	8:33 AM	25	54.04	51.52		
1/31/2018	8:34 AM	25	54.10	51.49		
1/31/2018	8:35 AM	25	54.12	51.48		
1/31/2018	8:36 AM	25	54.08	51.49		
1/31/2018	8:37 AM	25	54.10	51.51		
1/31/2018	8:38 AM	25	54.04	51.49		

**SHAWVER WELL COMPANY, INC.
TEST PUMPING REPORT**

Sears 66

Date: January 30-31, 2018

Date	Time	GPM	Sears 66			Water/Pumping Details
			PWL	Temp	Sand	
1/31/2018	8:39 AM	25	54.09	51.48		
1/31/2018	8:40 AM	25	54.11	51.45		
1/31/2018	8:41 AM	25	54.07	51.49		
1/31/2018	8:42 AM	25	54.06	51.47		
1/31/2018	8:43 AM	25	54.06	51.48		
1/31/2018	8:44 AM	25	54.10	51.47		
1/31/2018	8:45 AM	25	54.15	51.47		
1/31/2018	8:46 AM	25	54.08	51.47		
1/31/2018	8:47 AM	25	54.14	51.48		
1/31/2018	8:48 AM	25	54.15	51.51		
1/31/2018	8:49 AM	25	54.16	51.49		
1/31/2018	8:50 AM	25	54.09	51.48		
1/31/2018	8:51 AM	25	54.04	51.51		
1/31/2018	8:52 AM	25	54.12	51.49		
1/31/2018	8:53 AM	25	54.19	51.48		
1/31/2018	8:54 AM	25	54.14	51.48		
1/31/2018	8:55 AM	25	54.07	51.45		
1/31/2018	8:56 AM	25	54.16	51.49		
1/31/2018	8:57 AM	25	54.12	51.51		
1/31/2018	8:58 AM	25	54.10	51.51		
1/31/2018	8:59 AM	25	54.15	51.47		
1/31/2018	9:00 AM	25	54.14	51.45		
1/31/2018	9:01 AM	25	54.18	51.51		
1/31/2018	9:02 AM	25	54.10	51.47		
1/31/2018	9:03 AM	25	54.12	51.49		
1/31/2018	9:04 AM	25	54.12	51.48		
1/31/2018	9:05 AM	25	54.10	51.48		
1/31/2018	9:06 AM	25	54.13	51.51		
1/31/2018	9:07 AM	25	54.12	51.44		
1/31/2018	9:08 AM	25	54.09	51.50		
1/31/2018	9:09 AM	25	54.21	51.48		
1/31/2018	9:10 AM	25	54.05	51.45		
1/31/2018	9:11 AM	25	54.07	51.49		
1/31/2018	9:12 AM	25	54.11	51.48		
1/31/2018	9:13 AM	25	54.13	51.49		
1/31/2018	9:14 AM	25	54.13	51.48		
1/31/2018	9:15 AM	25	54.03	51.49		
1/31/2018	9:16 AM	25	54.08	51.50		
1/31/2018	9:17 AM	25	54.18	51.52		
1/31/2018	9:18 AM	25	54.13	51.46		
1/31/2018	9:19 AM	25	54.21	51.47		
1/31/2018	9:20 AM	25	54.16	51.53		
1/31/2018	9:21 AM	25	54.11	51.48		
1/31/2018	9:22 AM	25	54.13	51.47		
1/31/2018	9:23 AM	25	54.15	51.49		
1/31/2018	9:24 AM	25	54.19	51.49		
1/31/2018	9:25 AM	25	54.11	51.49		
1/31/2018	9:26 AM	25	54.10	51.48		
1/31/2018	9:27 AM	25	54.12	51.50		
1/31/2018	9:28 AM	25	54.11	51.47		

**SHAWVER WELL COMPANY, INC.
TEST PUMPING REPORT**

Sears 66

Date: January 30-31, 2018

Date	Time	GPM	Sears 66			Water/Pumping Details
			PWL	Temp	Sand	
1/31/2018	9:29 AM	25	54.15	51.47		
1/31/2018	9:30 AM	25	54.14	51.47		
1/31/2018	9:31 AM	25	54.16	51.49		
1/31/2018	9:32 AM	25	54.15	51.49		
1/31/2018	9:33 AM	25	54.15	51.48		
1/31/2018	9:34 AM	25	54.14	51.50		
1/31/2018	9:35 AM	25	54.19	51.48		
1/31/2018	9:36 AM	25	54.17	51.49		
1/31/2018	9:37 AM	25	54.14	51.51		
1/31/2018	9:38 AM	25	54.11	51.48		
1/31/2018	9:39 AM	25	54.16	51.48		
1/31/2018	9:40 AM	25	54.14	51.48		
1/31/2018	9:41 AM	25	54.46	51.50		
1/31/2018	9:42 AM	25	55.40	51.48		
1/31/2018	9:43 AM	25	55.82	51.50		
1/31/2018	9:44 AM	25	55.13	51.49		
1/31/2018	9:45 AM	25	54.84	51.49		
1/31/2018	9:46 AM	25	54.96	51.46		
1/31/2018	9:47 AM	25	55.67	51.53		
1/31/2018	9:48 AM	25	56.20	51.50		
1/31/2018	9:49 AM	25	56.46	51.49		
1/31/2018	9:50 AM	25	56.72	51.47		
1/31/2018	9:51 AM	25	56.74	51.47		
1/31/2018	9:52 AM	25	56.90	51.51		
1/31/2018	9:53 AM	25	56.96	51.46		
1/31/2018	9:54 AM	25	56.65	51.48		
1/31/2018	9:55 AM	25	55.77	51.49		
1/31/2018	9:56 AM	25	55.28	51.47		
1/31/2018	9:57 AM	25	54.91	51.52		
1/31/2018	9:58 AM	25	54.70	51.49		
1/31/2018	9:59 AM	25	54.97	51.49		
1/31/2018	10:00 AM	25	55.71	51.48		
1/31/2018	10:01 AM	25	55.99	51.48		
1/31/2018	10:02 AM	25	55.46	51.53		
1/31/2018	10:03 AM	25	55.16	51.48		
1/31/2018	10:04 AM	25	55.01	51.49		
1/31/2018	10:05 AM	25	54.77	51.48		
1/31/2018	10:06 AM	25	54.65	51.51		
1/31/2018	10:07 AM	25	54.69	51.45		
1/31/2018	10:08 AM	25	54.58	51.49		
1/31/2018	10:09 AM	25	54.56	51.50		
1/31/2018	10:10 AM	25	54.42	51.47		
1/31/2018	10:11 AM	25	54.35	51.50		
1/31/2018	10:12 AM	25	54.27	51.48		
1/31/2018	10:13 AM	25	54.28	51.45		
1/31/2018	10:14 AM	25	54.23	51.49		
1/31/2018	10:15 AM	25	54.23	51.52		
1/31/2018	10:16 AM	25	54.21	51.51		
1/31/2018	10:17 AM	25	54.18	51.48		

**SHAWVER WELL COMPANY, INC.
TEST PUMPING REPORT**

Sears 66

Date: January 30-31, 2018

Date	Time	GPM	Sears 66			Water/Pumping Details
			PWL	Temp	Sand	
1/31/2018	10:18 AM	25	54.18	51.44		
1/31/2018	10:19 AM	25	54.21	51.50		
1/31/2018	10:20 AM	25	54.18	51.48		
1/31/2018	10:21 AM	25	54.18	51.50		
1/31/2018	10:22 AM	25	54.19	51.52		
1/31/2018	10:23 AM	25	54.15	51.50		
1/31/2018	10:24 AM	25	54.15	51.47		
1/31/2018	10:25 AM	25	54.19	51.48		
1/31/2018	10:26 AM	25	54.14	51.48		
1/31/2018	10:27 AM	25	54.09	51.47		
1/31/2018	10:28 AM	25	54.14	51.51		
1/31/2018	10:29 AM	25	54.25	51.50		
1/31/2018	10:30 AM	25	54.24	51.46		
1/31/2018	10:31 AM	25	54.22	51.45		
1/31/2018	10:32 AM	25	54.14	51.47		
1/31/2018	10:33 AM	25	54.17	51.49		
1/31/2018	10:34 AM	25	54.13	51.51		
1/31/2018	10:35 AM	25	54.19	51.48		
1/31/2018	10:36 AM	25	54.19	51.48		
1/31/2018	10:37 AM	25	54.20	51.46		
1/31/2018	10:38 AM	25	54.17	51.48		
1/31/2018	10:39 AM	25	54.20	51.49		
1/31/2018	10:40 AM	25	54.17	51.46		
1/31/2018	10:41 AM	25	54.21	51.48		
1/31/2018	10:42 AM	25	54.14	51.50		
1/31/2018	10:43 AM	25	54.19	51.45		
1/31/2018	10:44 AM	25	54.21	51.48		
1/31/2018	10:45 AM	25	54.15	51.46		
1/31/2018	10:46 AM	25	54.15	51.51		
1/31/2018	10:47 AM	25	54.17	51.52		
1/31/2018	10:48 AM	25	54.14	51.51		
1/31/2018	10:49 AM	25	54.16	51.52		
1/31/2018	10:50 AM	25	54.21	51.45		
1/31/2018	10:51 AM	25	54.17	51.47		
1/31/2018	10:52 AM	25	54.23	51.49		
1/31/2018	10:53 AM	25	54.16	51.48		
1/31/2018	10:54 AM	25	54.19	51.48		
1/31/2018	10:55 AM	25	54.22	51.50		
1/31/2018	10:56 AM	25	54.19	51.49		
1/31/2018	10:57 AM	25	54.20	51.53		
1/31/2018	10:58 AM	25	54.18	51.49		
1/31/2018	10:59 AM	25	54.20	51.53		
1/31/2018	11:00 AM	25	54.16	51.50		
1/31/2018	11:01 AM	25	54.23	51.47		
1/31/2018	11:02 AM	25	54.20	51.47		
1/31/2018	11:03 AM	25	54.19	51.46		
1/31/2018	11:04 AM	25	54.22	51.49		

**SHAWVER WELL COMPANY, INC.
TEST PUMPING REPORT**

Sears 66

Date: January 30-31, 2018

Date	Time	GPM	Sears 66			Water/Pumping Details
			PWL	Temp	Sand	
1/31/2018	11:05 AM	25	54.15	51.47		
1/31/2018	11:06 AM	25	54.13	51.46		
1/31/2018	11:07 AM	25	54.15	51.50		
1/31/2018	11:08 AM	25	54.19	51.47		
1/31/2018	11:09 AM	25	54.21	51.50		
1/31/2018	11:10 AM	25	54.24	51.50		
1/31/2018	11:11 AM	25	54.11	51.48		
1/31/2018	11:12 AM	25	54.17	51.47		
1/31/2018	11:13 AM	25	54.23	51.51		
1/31/2018	11:14 AM	25	54.18	51.47		
1/31/2018	11:15 AM	25	54.15	51.53		
SHUTDOWN PUMP						
1/31/2018	11:16 AM	0	45.38	51.48		
1/31/2018	11:17 AM	0	35.78	51.52		
1/31/2018	11:18 AM	0	29.40	51.51		
1/31/2018	11:19 AM	0	25.03	51.51		
1/31/2018	11:20 AM	0	22.01	51.45		
1/31/2018	11:21 AM	0	19.87	51.51		
1/31/2018	11:22 AM	0	18.32	51.45		
1/31/2018	11:23 AM	0	17.14	51.47		
1/31/2018	11:24 AM	0	16.32	51.51		
1/31/2018	11:25 AM	0	15.69	51.48		
1/31/2018	11:26 AM	0	15.23	51.49		
1/31/2018	11:27 AM	0	14.81	51.51		
1/31/2018	11:28 AM	0	14.48	51.48		
1/31/2018	11:29 AM	0	14.68	51.48		
1/31/2018	11:30 AM	0	14.68	51.60		
1/31/2018	11:31 AM	0	14.23	51.66		
1/31/2018	11:32 AM	0	14.65	51.61		
1/31/2018	11:33 AM	0	14.22	51.58		
1/31/2018	11:34 AM	0	14.52	51.56		
1/31/2018	11:35 AM	0	14.16	51.59		
1/31/2018	11:36 AM	0	14.37	51.54		
1/31/2018	11:37 AM	0	14.08	51.51		
1/31/2018	11:38 AM	0	13.94	51.51		
1/31/2018	11:39 AM	0	13.50	51.51		
1/31/2018	11:40 AM	0	13.19	51.48		
1/31/2018	11:41 AM	0	12.97	51.53		
1/31/2018	11:42 AM	0	12.77	51.48		
1/31/2018	11:43 AM	0	12.62	51.52		
1/31/2018	11:44 AM	0	12.49	51.51		
1/31/2018	11:45 AM	0	12.39	51.47		
1/31/2018	11:46 AM	0	12.29	51.50		
1/31/2018	11:47 AM	0	12.21	51.49		
1/31/2018	11:48 AM	0	12.13	51.50		
1/31/2018	11:49 AM	0	12.06	51.51		
1/31/2018	11:50 AM	0	11.99	51.56		

**SHAWVER WELL COMPANY, INC.
TEST PUMPING REPORT**

Sears 66

Date: January 30-31, 2018

Date	Time	GPM	Sears 66			Water/Pumping Details
			PWL	Temp	Sand	
1/31/2018	11:51 AM	0	11.93	51.52		
1/31/2018	11:52 AM	0	11.87	51.52		
1/31/2018	11:53 AM	0	11.81	51.48		
1/31/2018	11:54 AM	0	11.75	51.55		
1/31/2018	11:55 AM	0	11.70	51.51		
1/31/2018	11:56 AM	0	11.65	51.54		
1/31/2018	11:57 AM	0	11.60	51.53		
1/31/2018	11:58 AM	0	11.55	51.49		
1/31/2018	11:59 AM	0	11.51	51.48		
1/31/2018	12:00 PM	0	11.46	51.52		
1/31/2018	12:01 PM	0	11.43	51.47		
1/31/2018	12:02 PM	0	11.38	51.48		
1/31/2018	12:03 PM	0	11.34	51.46		
1/31/2018	12:04 PM	0	11.29	51.49		
1/31/2018	12:05 PM	0	11.26	51.51		
1/31/2018	12:06 PM	0	11.22	51.48		
1/31/2018	12:07 PM	0	11.18	51.48		
1/31/2018	12:08 PM	0	11.14	51.49		
1/31/2018	12:09 PM	0	11.10	51.47		
1/31/2018	12:10 PM	0	11.07	51.49		
1/31/2018	12:11 PM	0	11.03	51.46		
1/31/2018	12:12 PM	0	11.00	51.50		
1/31/2018	12:13 PM	0	10.96	51.53		
1/31/2018	12:14 PM	0	10.93	51.49		
1/31/2018	12:15 PM	0	10.90	51.49		
1/31/2018	12:16 PM	0	10.87	51.52		
1/31/2018	12:17 PM	0	10.84	51.47		
1/31/2018	12:18 PM	0	10.81	51.49		
1/31/2018	12:19 PM	0	10.78	51.46		
1/31/2018	12:20 PM	0	10.76	51.50		
1/31/2018	12:21 PM	0	10.73	51.44		
1/31/2018	12:22 PM	0	10.70	51.48		
1/31/2018	12:23 PM	0	10.67	51.49		
1/31/2018	12:24 PM	0	10.64	51.50		
1/31/2018	12:25 PM	0	10.61	51.47		
1/31/2018	12:26 PM	0	10.59	51.44		
1/31/2018	12:27 PM	0	10.56	51.50		
1/31/2018	12:28 PM	0	10.53	51.47		
1/31/2018	12:29 PM	0	10.51	51.51		
1/31/2018	12:30 PM	0	10.49	51.46		
1/31/2018	12:31 PM	0	10.46	51.50		
1/31/2018	12:32 PM	0	10.43	51.50		
1/31/2018	12:33 PM	0	10.41	51.48		
1/31/2018	12:34 PM	0	10.39	51.46		
1/31/2018	12:35 PM	0	10.37	51.45		
1/31/2018	12:36 PM	0	10.35	51.44		
1/31/2018	12:37 PM	0	10.33	51.46		

**SHAWVER WELL COMPANY, INC.
TEST PUMPING REPORT**

Sears 66

Date: January 30-31, 2018

Date	Time	GPM	Sears 66			Water/Pumping Details
			PWL	Temp	Sand	
1/31/2018	12:38 PM	0	10.30	51.46		
1/31/2018	12:39 PM	0	10.28	51.46		
1/31/2018	12:40 PM	0	10.27	51.46		
1/31/2018	12:41 PM	0	10.24	51.49		
1/31/2018	12:42 PM	0	10.23	51.45		
1/31/2018	12:43 PM	0	10.21	51.46		
1/31/2018	12:44 PM	0	10.19	51.48		
1/31/2018	12:45 PM	0	10.17	51.47		
1/31/2018	12:46 PM	0	10.15	51.48		
1/31/2018	12:47 PM	0	10.12	51.48		
1/31/2018	12:48 PM	0	10.10	51.45		
1/31/2018	12:49 PM	0	10.08	51.47		
1/31/2018	12:50 PM	0	10.06	51.49		
1/31/2018	12:51 PM	0	10.05	51.46		
1/31/2018	12:52 PM	0	10.03	51.49		
1/31/2018	12:53 PM	0	10.02	51.50		
1/31/2018	12:54 PM	0	9.99	51.48		
1/31/2018	12:55 PM	0	9.98	51.46		
1/31/2018	12:56 PM	0	9.96	51.48		
1/31/2018	12:57 PM	0	9.94	51.50		
1/31/2018	12:58 PM	0	9.92	51.50		
1/31/2018	12:59 PM	0	9.92	51.48		
1/31/2018	1:00 PM	0	9.89	51.48		
1/31/2018	1:01 PM	0	9.88	51.47		
1/31/2018	1:02 PM	0	9.86	51.45		
1/31/2018	1:03 PM	0	9.84	51.50		
1/31/2018	1:04 PM	0	9.83	51.48		
1/31/2018	1:05 PM	0	9.81	51.48		
1/31/2018	1:06 PM	0	9.80	51.44		
1/31/2018	1:07 PM	0	9.78	51.52		
1/31/2018	1:08 PM	0	9.77	51.49		
1/31/2018	1:09 PM	0	9.75	51.52		
1/31/2018	1:10 PM	0	9.74	51.45		
1/31/2018	1:11 PM	0	9.72	51.48		
1/31/2018	1:12 PM	0	9.71	51.49		
1/31/2018	1:13 PM	0	9.70	51.44		
1/31/2018	1:14 PM	0	9.68	51.49		
1/31/2018	1:15 PM	0	9.67	51.46		
1/31/2018	1:16 PM	0	9.64	51.51		
1/31/2018	1:17 PM	0	9.63	51.47		