88953

001

Oasis Well & Pump Co.

1332 N. Franklin St
Manchester, Ia 52057
563-927-6503
888-666-6503

WELL TEST DATA REPORT

Customer Dutrac City Dubuque
Location _____ Well No. DWSID # IA 3126213
Size Casing 6" Total Depth 373 Construction Air Rotary
Make Pump _____ Model No. _____ No. of Stages _____
Diameter _____ Total Setting _____ Air Line Length _____
Meter Used _____ Static Level _____

DATE	TIME	GPM	P.S.	D.D.	WL SWL	P.S.I.	TEMP DISCHARGE DESCRIPTION
4-4-18	10:20A	30	350		62'		51.4
	10:21	30					
	10:22	30					
	10:23	30					
	10:24	29			88'		
	10:25	29					
	10:26	28					
	10:27	28					
	10:28	27		41'	109'		
	10:29	27					
	10:30	27					
	10:31	27					
	10:32	27					
	10:33	27					
	10:34	27					
	10:35	27					
	10:38	27					
	10:41	26					
	10:44	26					
	10:47	26					
	10:50	26					
	10:57	26					
	11:02	26					
	11:07	26					
	11:12	26					56.5
	11:17	26			105		
	11:22	26					

88953

2

001

Oasis Well & Pump Co.

1332 N. Franklin St
Manchester, Ia 52057
563-927-6503
888-666-6503

WELL TEST DATA REPORT

Customer Dutton City Dyersville
Location _____ Well No. / IA 3126 213
Size Casing _____ Total Depth _____ Construction _____
Make Pump _____ Model No. _____ No. of Stages _____
Diameter _____ Total Setting _____ Air Line Length _____
Meter Used _____ Static Level _____

DATE	TIME	GPM	P.I.	D.D.	WL SPE.	P.S.I.	TEMP DISCHARGE DESCRIPTION
	11:32	26			109		61.3
	11:42	26			109		61.5
	11:52	26			109		62.6
	12:02	26			109		63
	12:12	26			109		64
	12:22	26			109		63.9
	12:32	26			110		58.9
	12:42	26			110		
	12:52	26		43'	110		63
	1:02	26		42'	109		59.8
	1:12	26		43'	110		51.9
	1:22	26		43'	110		55.8
	2:22	26			110		68.16
	3:22	26			110		64.3
	4:22	26			109		65.9
	5:22	26			111		61
	6:22	26			109		67
	7:22	26			111		61.8°
	8:22	26			111		60
	9:22	26			110		64.1
	10:22	26			111		67
	11:22 P	26			111		54.3
	12:22 A	26			111		52.6
	1:22	26			111		52.8
	2:22	26			111		49.3
	3:22	26			111		49.4
	4:22	26			111		50.2
	5:22	26			111		49.2

88953
3

001

Oasis Well & Pump Co.

1332 N. Franklin St
Manchester, Ia 52057
563-927-8503
888-666-8503

WELL TEST DATA REPORT

Customer Nutrac City Dubuque
Location Well No. Ia 3124213
Size Casing Total Depth Construction
Make Pump Model No. No. of Stages
Diameter Total Setting Air Line Length
Meter Used Static Level

DATE	TIME	GPM	P.I.	D.D.	WL S.E.	P.S.I.	TEMP DISCHARGE DESCRIPTION
	6:20	26			111	50.3	
	7:20	26			111	55.2	
	8:20	26			111	55	
	9:20	26			111	57	
	10:20	26			111	57	
		End test pumping					
water	level	recovery					
	10:20				118		
#	10:24				90		
	10:27				76		
	10:30				75		
	10:34				74		
	10:56				72		
	11:32				71		
	12:52				70'		