9-230

UNITED STATES
DEPARTMENT OF THE INTERIOR
GEOLOGICAL SURVEY

W-6404

File No. { Washington _____ / District _____

Strawberry Point Creamery Well # 3 — March 2, 1954

Time	D/W		Remarks
7.55	AM -	129.7 feet	
12.25	PM	129.6 feet	
1.40	PM	129.6 feet	
Start	at	1:40 PM	
	Elect	Line	refused to work
2.08	140.5'		pumping 190 gpm Temp 50°F
2.22	141.4'		
2.40	143.2'		
2:53	144.1'		pumping 170 gpm Temp 50°F
3:15	145.2'		
			Speed increased to 280 gpm Temp 50°F
3:20	157.8'		
4:00	160.2'		
		Elect. Line again refused to work.	
		pumped until 10:30 PM.	
		Estimated depth to water at 10:30	170' + or -

U. S. GOVERNMENT PRINTING OFFICE 16—48721-1