



CAHOY PUMP SERVICE

(833-728-1288)

SUMNER, IA
Corporate Office

MARNE, IA

Durand, IL

Lincoln, IL

Cahoy High Plains, WY

WELL TEST DATA SHEET

CLIENT: Osceola RW

WELL: R-1

DATE: 5/4/21

TESTED BY: Ray S.

PUMP MODEL: 7WC

AIRLINE LENGTH: Sounder

WELL DIAMETER: 12"

ORIFICE SIZE: 6" Meter

DEPTH OF WELL: 48.5'

MOTOR: Franklin 25hp/460v

STATIC WATER LEVEL: R1 – 9.6', OB – 11'

GENERATOR USED: No **Yes** Gen 1/Gen 2

BEGIN HOURS: 3382 END HOURS: 3386

STEP-RATE TEST

CONSTANT RATE TEST

PRE-TREATMENT

POST –TREATMENT

MEASUREMENT TAKEN FROM THE TOP OF THE WELL CASING WHICH IS 1.5' FEET FROM EXISTING GROUND/FLOOR LEVEL.

