



CAHOY PUMP SERVICE

(833-728-1288)

SUMNER, IA
Corporate Office

MARNE, IA

Durand, IL

Lincoln, IL

Cahoy High Plains, WY

WELL TEST DATA SHEET

CLIENT: Osceola

WELL: R1

DATE: 5/17/21

TESTED BY: Ray

PUMP MODEL: Flowise 7wc

AIRLINE LENGTH:

WELL DIAMETER: 12"

ORIFICE SIZE:

DEPTH OF WELL: 40'

MOTOR:

STATIC WATER LEVEL: P 9.5 M 10.9

GENERATOR USED: No **Yes** Gen 1/Gen 2

BEGIN HOURS: 3443 END HOURS: 3447

STEP-RATE TEST

CONSTANT RATE TEST

PRE-TREATMENT

POST -TREATMENT

MEASUREMENT TAKEN FROM THE TOP OF THE WELL CASING WHICH IS 16 FEET FROM EXISTING GROUND/FLOOR LEVEL.

