



CAHOY PUMP SERVICE

(833-728-1288)

SUMNER, IA
Corporate Office

MARNE, IA

Durand, IL

Lincoln, IL

Cahoy High Plains, WY

WELL TEST DATA SHEET

CLIENT: OCRW

WELL: D-1

DATE: 11/30/21

TESTED BY: Curtis, Dan & Llyod

PUMP MODEL: Ours

WELL DIAMETER: 12"

DEPTH OF WELL: 45' 7"

STATIC WATER LEVEL: 11.2'

AIRLINE LENGTH: N/A

ORIFICE SIZE: 5"

MOTOR: Ours

GENERATOR USED: No **Yes** **Gen 1**/Gen 2

BEGIN HOURS: 3580.6 END HOURS: 3628

STEP-RATE TEST

CONSTANT RATE TEST

PRE-TREATMENT

POST -TREATMENT

MEASUREMENT TAKEN FROM THE TOP OF THE WELL CASING WHICH IS 2 FEET FROM EXISTING GROUND/FLOOR LEVEL.

