

Northway Well and Pump Co.

4895 8th Avenue
Marion, Iowa 52302
319-377-6339
1-800-747-6339

100 North 6th Street
Waukee, Iowa 50263
515-987-4575
1-800-747-4575

WELL TEST DATA REPORT

Customer City of Ankeny City Ankeny, IA
Location 1102 SE Creekview Dr. Ankeny, IA Well No. ASR #7
Size Casing 24" - 18" Total Depth 2477' Construction Jordan
Make Pump Mid America Model No. 14RH No. of Stages 8
Diameter 12" Total Setting 608' Air Line Length 450'
Meter Used 12" Static Level 382'

DATE	TIME	GPM	P.L.	D.D.	S.C.	PSI	Water Description
09/06/2022	9:00am	3000	382'				Clear
	9:01	3000	450'	68'	44.12		
	9:02	3000	461'	79'	37.97	ASR #1	Running 642'
	9:03	3000	468'	86'	34.88		840 GPM
	9:04	3000	471'	89'	33.70	ASR #2	Running 525'
	9:05	3000	472'	90'	33.33		1694 GPM
	9:10	3000	473'	91'	32.97		
	9:15	3000	475'	93'	32.26		Wells remained the
	9:20	3000	475'	93'	32.26		Same throughout test
	9:25	3000	475'	93'	32.26		
	9:30	3000	475'	93'	32.26		
	9:45	3000	476'	94'	31.91		
	10:00	3000	478'	94'	31.91		"0" Sand
	11:00	3000	478'	94'	31.91		
	12:00	3000	480'	98'	30.61		
	1:00pm	3000	480'	98'	30.61		
	2:00	3000	481'	99'	30.30		
	3:00	3000	481'	99'	30.30		
	4:00	3000	481'	99'	30.30		
	5:00	3000	482'	100'	30		
	6:00	3000	483'	101'	29.70		
	7:00	3000	483'	101'	29.70		
	8:00	3000	483'	101'	29.70		
	9:00	3000	483'	101'	29.70		
	10:00	3000	484'	102'	29.41		
	11:00	3000	484'	102'	29.41		
09/07/2022	12:00	3000	484'	102'	29.41		
	1:00am	3000	484'	102'	29.41		
	2:00	3000	484'	102'	29.41		

Northway Well and Pump Co.

4895 8th Avenue
Marion, Iowa 52302
319-377-6339
1-800-747-6339

100 North 6th Street
Waukee, Iowa 50263
515-987-4575
1-800-747-4575

WELL TEST DATA REPORT

PAGE -2-

Customer City of Ankeny City Ankeny
Location 1102 SE Creekview Dr. Ankeny, IA Well No. ASR #7

DATE	TIME	GPM	P.L.	D.D.	S.C.	P.S.I.	TEMP DISCHARGE DESCRIPTION
09/07/2022	3:00am	3000	484'	102'	29.41		
	4:00	3000	484'	102'	29.41		
	5:00	3000	484'	102'	29.41		
	6:00	3000	485'	103'	29.12		
	7:00	3000	485'	103'	29.12		
	8:00	3000	486'	104'	28.85		
	9:00	3000	486'	104'	28.85		
	10:00	3000	486'	104'	28.85		
	11:00	3000	486'	104'	28.85		
	12:00	3000	486'	104'	28.85		Clear "0" Sand
	1:00pm	3000	486'	104'	28.85		
	2:00	3000	486'	104'	28.85		
	3:00	3000	486'	104'	28.85		
	4:00	3000	486'	104'	28.85		
	5:00	3000	486'	104'	28.85		
	6:00	3000	486'	104'	28.85		
	7:00	3000	488'	106'	28.30		
	8:00	3000	488'	106'	28.30		
	9:00	3000	488'	106'	28.30		
	10:00	3000	488'	106'	28.30		
	11:00	3000	488'	106'	28.30		
09/08/2022	12:00	3000	488'	106'	28.30		Clear "0" Sand
	1:00am	3000	488'	106'	28.30		
	2:00	3000	488'	106'	28.30		
	3:00	3000	488'	106'	28.30		
	4:00	3000	488'	106'	28.30		
	5:00	3000	488'	106'	28.30		
	6:00	3000	488'	106'	28.30		
	7:00	3000	488'	106'	28.30		
	8:00	3000	488'	106'	28.30		

Northway Well and Pump Co.

4895 8th Avenue
Marion, Iowa 52302
319-377-6339
1-800-747-6339

100 North 6th Street
Waukee, Iowa 50263
515-987-4575
1-800-747-4575

WELL TEST DATA REPORT

PAGE -3-

Customer City of Ankeny City Ankeny
Location 1102 SE Creekview Dr. Ankeny, IA Well No. ASR #7

DATE	TIME	GPM	P.L.	D.D.	S.C.	P.S.I.	TEMP DISCHARGE DESCRIPTION
09/08/2022	9:00am	3000	488'	106'	28.30		Clear "0" Sand
	10:00	3000	488'	106'	28.30		
	11:00	3000	488'	106'	28.30		
	12:00	3000	488'	106'	28.30		
	1:00pm	3000	488'	106'	28.30		
	2:00	3000	488'	106'	28.30		
	3:00	3000	488'	106'	28.30		
	4:00	3000	488'	106'	28.30		
	5:00	3000	488'	106'	28.30		
	6:00	3000	488'	106'	28.30		
	7:00	3000	488'	106'	28.30		
	8:00	3000	488'	106'	28.30		
	9:00	3000	488'	106'	28.30		
	10:00	3000	488'	106'	28.30		
	11:00	3000	488'	106'	28.30		
09/09/2022	12:00	3000	488'	106'	28.30		
	1:00am	3000	488'	106'	28.30		
	2:00	3000	488'	106'	28.30		
	3:00	3000	488'	106'	28.30		
	4:00	3000	488'	106'	28.30		
	5:00	3000	488'	106'	28.30		
	6:00	3000	488'	106'	28.30		
	7:00	3000	488'	106'	28.30		
	8:00	3000	488'	106'	28.30		
	9:00	3000	488'	106'	28.30		
Recovery	9:01		440'				
	9:02		416'				
	9:03		403'				
	9:04		398'				
	9:05		396'				

Northway Well and Pump Co.

100 North 6th Street
Waukee, Iowa 50263
515-987-4575
1-800-747-4575

WELL TEST DATA REPORT

PAGE -4-

Customer City of Ankeny City Ankeny
Location 1102 SE Creekview Dr. Ankeny, IA Well No. ASR #7

[illegible]