

TEST PUMPING REPORT

95928

Ventura, IA - Deep Well

Well #4

Ventura, IA

Date: April 10, 2023

Test Pump Crew:		Mike Sparks				Length of Casing Above Ground:	
Depth of Well:		454'		430'		36"	
Size of Well:		8"		8"		Miscellaneous: Readings were taken from the top of the casing. 24 Hour Test Start Time: 9:49 AM 04/10/23 End Time: 9:59 AM 04/11/23 .5 Hour Recovery	
SWL:		56.03'		57.92'			
Pump Model:		7CLC					
Pump HP:		60 HP					
Length of Transducer:		168'					
Depth of Pump:		168'					
		Well #4			Well #3		
Date/Time	GPM	PWL	Temp	Sand	SWL	Temp	Water/Pumping Details
4/10/23 9:25 AM	0	55.98	51.64		58.03	50.39	
4/10/23 9:26 AM	0	56.04	51.66		58.02	50.38	
4/10/23 9:27 AM	0	56.04	51.62		57.94	50.33	
4/10/23 9:28 AM	0	56.01	51.75		58.00	50.33	
4/10/23 9:29 AM	0	56.04	51.80		58.02	50.34	
4/10/23 9:30 AM	0	56.04	51.84		57.98	50.35	
4/10/23 9:31 AM	0	56.00	51.87		58.05	50.32	
4/10/23 9:32 AM	0	55.98	51.89		57.97	50.35	
4/10/23 9:33 AM	0	56.00	51.89		57.89	50.31	
4/10/23 9:34 AM	0	56.03	51.89		57.97	50.32	
4/10/23 9:35 AM	0	56.04	51.88		58.03	50.36	
4/10/23 9:36 AM	0	56.02	51.90		58.03	50.36	
4/10/23 9:37 AM	0	56.00	51.92		57.99	50.31	
4/10/23 9:38 AM	0	55.99	51.92		58.04	50.33	
4/10/23 9:39 AM	0	56.02	51.92		58.04	50.36	
4/10/23 9:40 AM	0	56.02	51.84		58.03	50.39	
4/10/23 9:41 AM	0	56.01	51.77		57.94	50.31	
4/10/23 9:42 AM	0	56.03	51.74		58.00	50.34	
4/10/23 9:43 AM	0	56.02	51.71		58.03	50.35	
4/10/23 9:44 AM	0	56.04	51.69		58.02	50.34	
4/10/23 9:45 AM	0	56.02	51.67		58.02	50.32	
4/10/23 9:46 AM	0	56.01	51.67		57.98	50.35	
4/10/23 9:47 AM	0	56.03	51.66		57.96	50.36	
4/10/23 9:48 AM	0	56.03	51.65		57.92	50.33	
START UP PUMP							
4/10/23 9:49 AM	420	61.64	51.65		58.18	50.33	
4/10/23 9:50 AM	420	65.19	51.77		58.38	50.34	
4/10/23 9:51 AM	420	65.36	51.96		58.50	50.35	
4/10/23 9:52 AM	420	65.49	51.93		58.42	50.32	
4/10/23 9:53 AM	420	65.57	51.72		58.49	50.36	
4/10/23 9:54 AM	420	68.40	51.44		58.51	50.36	
4/10/23 9:55 AM	420	70.59	51.17		58.62	50.38	
4/10/23 9:56 AM	420	70.66	50.97		58.66	50.35	
4/10/23 9:57 AM	420	70.63	50.76		58.70	50.34	
4/10/23 9:58 AM	420	70.66	50.60		58.71	50.36	
4/10/23 9:59 AM	420	70.87	50.48		58.76	50.38	
4/10/23 10:00 AM	420	71.36	50.37		58.70	50.35	
4/10/23 10:01 AM	420	70.80	50.24		58.76	50.35	
4/10/23 10:02 AM	420	70.89	50.11		58.75	50.34	
4/10/23 10:03 AM	420	71.32	50.02		58.83	50.33	
4/10/23 10:04 AM	420	71.05	49.95		58.72	50.35	
4/10/23 10:05 AM	420	70.68	49.89		58.75	50.32	
4/10/23 10:06 AM	420	70.94	49.87		58.79	50.35	
4/10/23 10:07 AM	420	71.11	49.86		58.81	50.37	
4/10/23 10:08 AM	420	71.12	49.80		58.82	50.35	
4/10/23 10:09 AM	420	70.97	49.78		58.74	50.34	
4/10/23 10:10 AM	420	71.30	49.78		58.81	50.36	
4/10/23 10:11 AM	420	71.00	49.78		58.73	50.35	

TEST PUMPING REPORT

95928

Ventura, IA - Deep Well

Well #4

Ventura, IA

Date: April 10, 2023

Date/Time	GPM	Well #4			Well #3		Water/Pumping Details
		PWL	Temp	Sand	SWL	Temp	
4/10/23 10:12 AM	420	71.17	49.80		58.80	50.35	
4/10/23 10:13 AM	420	71.64	49.78		58.83	50.34	
4/10/23 10:14 AM	420	71.18	49.75		58.74	50.34	
4/10/23 10:15 AM	420	71.06	49.74		58.86	50.37	
4/10/23 10:16 AM	420	71.37	49.69		58.77	50.39	
4/10/23 10:17 AM	420	71.40	49.67		58.82	50.35	
4/10/23 10:18 AM	420	71.28	49.66		58.79	50.38	
4/10/23 10:19 AM	420	71.48	49.65		58.88	50.35	
4/10/23 10:20 AM	420	71.23	49.64		58.78	50.36	
4/10/23 10:21 AM	420	70.84	49.65		58.83	50.37	
4/10/23 10:22 AM	420	71.41	49.65		58.81	50.36	
4/10/23 10:23 AM	420	71.24	49.64		58.80	50.36	
4/10/23 10:24 AM	420	71.11	49.63		58.81	50.37	
4/10/23 10:25 AM	420	71.46	49.53		58.86	50.35	
4/10/23 10:30 AM	420	71.18	49.57		58.81	50.37	
4/10/23 10:35 AM	420	71.52	49.43		58.89	50.33	
4/10/23 10:40 AM	440	68.84	49.42		58.80	50.34	
4/10/23 10:45 AM	440	69.20	49.62		58.79	50.34	
4/10/23 10:50 AM	440	68.87	49.68		58.83	50.38	
4/10/23 10:55 AM	440	69.08	49.63		58.84	50.34	
4/10/23 11:00 AM	440	68.79	49.62		58.87	50.36	
4/10/23 11:05 AM	440	69.83	49.67		58.85	50.35	
4/10/23 11:10 AM	440	69.72	49.79		58.84	50.34	
4/10/23 11:15 AM	440	68.95	49.80		58.80	50.38	
4/10/23 11:20 AM	440	69.59	49.81		58.83	50.33	
4/10/23 11:25 AM	440	69.38	49.84		58.80	50.34	
4/10/23 11:35 AM	440	69.33	49.74		58.84	50.36	
4/10/23 11:45 AM	400	67.90	49.57		58.84	50.37	
4/10/23 11:55 AM	400	68.00	49.88		58.83	50.37	
4/10/23 12:05 PM	400	68.13	49.84		58.85	50.34	
4/10/23 12:15 PM	380	67.88	49.81		58.77	50.32	
4/10/23 12:25 PM	380	68.25	49.64		58.81	50.36	
4/10/23 12:40 PM	380	68.30	49.48		58.84	50.34	
4/10/23 12:55 PM	380	68.13	49.48		58.89	50.38	
4/10/23 1:10 PM	380	67.87	49.48		58.81	50.35	
4/10/23 1:25 PM	380	68.38	49.50		58.93	50.33	
4/10/23 1:55 PM	380	68.22	49.46		58.88	50.37	
4/10/23 2:25 PM	380	68.31	49.45		58.93	50.34	
4/10/23 2:55 PM	380	68.26	49.80		58.90	50.33	
4/10/23 3:25 PM	380	68.32	49.53		58.87	50.34	
4/10/23 3:55 PM	380	68.28	49.56		58.92	50.33	
4/10/23 4:25 PM	380	67.92	49.41		58.87	50.33	
4/10/23 4:55 PM	380	68.35	49.41		58.95	50.36	
4/10/23 5:25 PM	380	68.00	49.58		59.00	50.34	
4/10/23 5:55 PM	380	68.38	49.51		58.96	50.36	
4/10/23 6:25 PM	380	67.98	49.49		58.94	50.33	
4/10/23 6:55 PM	380	68.11	49.39		58.94	50.36	
4/10/23 7:25 PM	380	68.42	49.48		58.90	50.35	
4/10/23 7:55 PM	380	68.06	49.48		58.92	50.36	
4/10/23 8:25 PM	380	68.41	49.50		58.94	50.35	
4/10/23 8:55 PM	380	68.58	49.39		58.89	50.34	
4/10/23 9:25 PM	380	68.11	49.52		58.84	50.35	
4/10/23 9:55 PM	380	68.34	49.53		58.86	50.34	
4/10/23 10:25 PM	380	68.28	49.44		58.87	50.32	
4/10/23 10:55 PM	380	68.31	49.53		58.86	50.38	
4/10/23 11:25 PM	380	68.56	49.54		58.88	50.34	
4/10/23 11:55 PM	380	68.19	49.46		58.90	50.39	

TEST PUMPING REPORT

95928

Ventura, IA - Deep Well

Well #4

Ventura, IA

Date: April 10, 2023

Date/Time	GPM	Well #4			Well #3		Water/Pumping Details
		PWL	Temp	Sand	SWL	Temp	
4/11/23 12:25 AM	380	68.56	49.46		58.91	50.36	
4/11/23 12:55 AM	380	68.29	49.36		58.82	50.37	
4/11/23 1:25 AM	380	68.45	49.50		58.89	50.37	
4/11/23 1:55 AM	380	68.60	49.51		58.91	50.32	
4/11/23 2:25 AM	380	68.19	49.42		58.93	50.36	
4/11/23 2:55 AM	380	68.45	49.48		58.92	50.37	
4/11/23 3:25 AM	380	68.57	49.40		58.92	50.33	
4/11/23 3:55 AM	380	68.30	49.49		58.90	50.35	
4/11/23 4:25 AM	380	68.44	49.48		58.97	50.30	
4/11/23 4:55 AM	380	68.38	49.51		58.94	50.33	
4/11/23 5:25 AM	380	68.56	49.46		58.94	50.35	
4/11/23 5:55 AM	380	68.40	49.43		58.95	50.35	
4/11/23 6:25 AM	380	68.80	49.47		58.94	50.33	
4/11/23 6:55 AM	380	68.56	49.43		58.94	50.36	
4/11/23 7:25 AM	380	68.62	49.43		58.95	50.38	
4/11/23 7:26 AM	380	68.76	49.35		58.95	50.35	
4/11/23 7:27 AM	380	68.71	49.40		59.01	50.37	
4/11/23 7:28 AM	380	68.72	49.40		59.01	50.37	
4/11/23 7:29 AM	380	68.18	49.42		58.98	50.33	
4/11/23 7:30 AM	380	68.40	49.41		58.96	50.32	
4/11/23 7:31 AM	380	68.36	49.49		58.98	50.35	
4/11/23 7:32 AM	380	68.71	49.41		58.95	50.39	
4/11/23 7:33 AM	380	68.69	49.42		58.96	50.32	
4/11/23 7:34 AM	380	68.44	49.47		59.00	50.36	
4/11/23 7:35 AM	380	68.42	49.43		58.96	50.35	
4/11/23 7:36 AM	380	68.71	49.38		58.96	50.34	
4/11/23 7:37 AM	380	68.63	49.42		58.96	50.31	
4/11/23 7:38 AM	380	68.61	49.40		58.97	50.33	
4/11/23 7:39 AM	380	68.25	49.44		59.00	50.32	
4/11/23 7:40 AM	380	68.37	49.47		59.01	50.38	
4/11/23 7:41 AM	380	68.41	49.43		58.99	50.38	
4/11/23 7:42 AM	380	68.54	49.40		58.93	50.36	
4/11/23 7:43 AM	380	68.60	49.39		58.99	50.36	
4/11/23 7:44 AM	380	68.34	49.46		58.99	50.36	
4/11/23 7:45 AM	380	68.23	49.45		58.99	50.34	
4/11/23 7:46 AM	380	68.51	49.46		58.95	50.35	
4/11/23 7:47 AM	380	68.65	49.43		59.04	50.36	
4/11/23 7:48 AM	380	68.83	49.45		58.98	50.37	
4/11/23 7:49 AM	380	68.40	49.40		58.97	50.38	
4/11/23 7:50 AM	380	68.38	49.39		59.02	50.37	
4/11/23 7:51 AM	380	68.68	49.47		58.93	50.38	
4/11/23 7:52 AM	380	68.23	49.45		59.02	50.34	
4/11/23 7:53 AM	380	68.28	49.52		58.98	50.37	
4/11/23 7:54 AM	380	68.58	49.57		58.97	50.33	
4/11/23 7:55 AM	380	68.47	49.54		59.06	50.29	
4/11/23 7:56 AM	380	68.85	49.55		58.97	50.35	
4/11/23 7:57 AM	380	68.32	49.47		59.07	50.40	
4/11/23 7:58 AM	380	68.73	49.51		58.98	50.33	
4/11/23 7:59 AM	380	68.77	49.52		58.99	50.35	
4/11/23 8:00 AM	380	68.15	49.43		58.99	50.37	
4/11/23 8:01 AM	380	68.54	49.54		58.94	50.35	
4/11/23 8:02 AM	380	68.54	49.62		58.90	50.36	
4/11/23 8:03 AM	380	68.30	49.66		58.97	50.33	
4/11/23 8:04 AM	380	68.14	49.69		59.04	50.32	
4/11/23 8:05 AM	380	68.54	49.63		58.91	50.39	
4/11/23 8:06 AM	380	68.67	49.60		59.01	50.34	
4/11/23 8:07 AM	380	68.97	49.58		59.01	50.32	

TEST PUMPING REPORT

95928

Ventura, IA - Deep Well

Well #4

Ventura, IA

Date: April 10, 2023

Date/Time	GPM	Well #4			Well #3		Water/Pumping Details
		PWL	Temp	Sand	SWL	Temp	
4/11/23 8:08 AM	380	68.52	49.56		59.00	50.33	
4/11/23 8:09 AM	380	68.69	49.52		58.97	50.34	
4/11/23 8:10 AM	380	68.70	49.51		58.94	50.40	
4/11/23 8:11 AM	380	68.40	49.49		58.95	50.36	
4/11/23 8:12 AM	380	68.64	49.56		58.95	50.39	
4/11/23 8:13 AM	380	68.64	49.61		59.05	50.41	
4/11/23 8:14 AM	380	68.69	49.61		58.93	50.34	
4/11/23 8:15 AM	380	68.30	49.55		58.99	50.37	
4/11/23 8:16 AM	380	68.34	49.51		58.97	50.36	
4/11/23 8:17 AM	380	68.69	49.48		58.95	50.34	
4/11/23 8:18 AM	380	68.20	49.49		58.97	50.34	
4/11/23 8:19 AM	380	68.17	49.42		58.96	50.33	
4/11/23 8:20 AM	380	68.68	49.49		58.96	50.35	
4/11/23 8:21 AM	380	68.77	49.42		58.94	50.41	
4/11/23 8:22 AM	380	68.81	49.42		58.89	50.37	
4/11/23 8:23 AM	380	68.39	49.44		58.86	50.35	
4/11/23 8:24 AM	380	68.58	49.49		58.99	50.34	
4/11/23 8:25 AM	380	68.20	49.51		58.93	50.30	
4/11/23 8:26 AM	380	68.85	49.53		59.02	50.38	
4/11/23 8:27 AM	380	68.82	49.49		58.98	50.38	
4/11/23 8:28 AM	380	68.58	49.41		59.03	50.35	
4/11/23 8:29 AM	380	68.45	49.40		58.95	50.34	
4/11/23 8:30 AM	380	68.46	49.36		59.06	50.31	
4/11/23 8:31 AM	380	68.78	49.35		58.97	50.34	
4/11/23 8:32 AM	380	68.45	49.35		58.95	50.37	
4/11/23 8:33 AM	380	68.40	49.30		58.99	50.34	
4/11/23 8:34 AM	380	68.48	49.32		58.97	50.36	
4/11/23 8:35 AM	380	68.82	49.32		58.92	50.37	
4/11/23 8:36 AM	380	68.64	49.29		58.93	50.36	
4/11/23 8:37 AM	380	68.47	49.34		58.95	50.39	
4/11/23 8:38 AM	380	68.36	49.36		58.97	50.35	
4/11/23 8:39 AM	380	68.55	49.46		58.98	50.35	
4/11/23 8:40 AM	380	68.47	49.52		59.01	50.38	
4/11/23 8:41 AM	380	68.36	49.53		58.95	50.36	
4/11/23 8:42 AM	380	68.72	49.55		59.03	50.38	
4/11/23 8:43 AM	380	68.31	49.57		59.04	50.35	
4/11/23 8:44 AM	380	68.70	49.60		59.01	50.33	
4/11/23 8:45 AM	380	68.50	49.63		58.97	50.38	
4/11/23 8:46 AM	380	68.68	49.65		58.97	50.36	
4/11/23 8:47 AM	380	68.77	49.65		59.00	50.35	
4/11/23 8:48 AM	380	68.54	49.64		59.00	50.37	
4/11/23 8:49 AM	380	68.48	49.62		59.01	50.35	
4/11/23 8:50 AM	380	68.24	49.61		59.05	50.37	
4/11/23 8:51 AM	380	68.73	49.60		58.93	50.36	
4/11/23 8:52 AM	380	68.72	49.62		59.13	50.36	
4/11/23 8:53 AM	380	68.55	49.62		58.86	50.37	
4/11/23 8:54 AM	380	68.58	49.60		58.94	50.38	
4/11/23 8:55 AM	380	68.65	49.61		58.95	50.34	
4/11/23 8:56 AM	380	68.61	49.63		59.01	50.38	
4/11/23 8:57 AM	380	68.47	49.50		58.98	50.36	
4/11/23 8:58 AM	380	68.67	49.41		58.94	50.36	
4/11/23 8:59 AM	380	68.46	49.35		59.00	50.34	
4/11/23 9:00 AM	380	68.80	49.32		59.02	50.38	
4/11/23 9:01 AM	380	68.69	49.31		58.98	50.36	
4/11/23 9:02 AM	380	68.38	49.41		59.09	50.34	
4/11/23 9:03 AM	380	68.65	49.49		58.98	50.34	
4/11/23 9:04 AM	380	68.46	49.48		58.92	50.40	

TEST PUMPING REPORT

95928

Ventura, IA - Deep Well

Well #4

Ventura, IA

Date: April 10, 2023

Date/Time	GPM	Well #4			Well #3		Water/Pumping Details
		PWL	Temp	Sand	SWL	Temp	
4/11/23 9:05 AM	380	68.72	49.42		58.94	50.34	
4/11/23 9:06 AM	380	68.83	49.36		58.97	50.39	
4/11/23 9:07 AM	380	68.23	49.37		58.98	50.40	
4/11/23 9:08 AM	380	68.67	49.36		58.94	50.29	
4/11/23 9:09 AM	380	68.54	49.34		58.95	50.38	
4/11/23 9:10 AM	380	68.65	49.29		58.91	50.31	
4/11/23 9:11 AM	380	68.58	49.28		58.94	50.29	
4/11/23 9:12 AM	380	68.28	49.33		58.95	50.36	
4/11/23 9:13 AM	380	68.62	49.26		58.94	50.40	
4/11/23 9:14 AM	380	68.39	49.27		58.97	50.35	
4/11/23 9:15 AM	380	68.76	49.35		58.91	50.36	
4/11/23 9:16 AM	380	68.47	49.34		59.06	50.36	
4/11/23 9:17 AM	380	68.64	49.38		59.05	50.33	
4/11/23 9:18 AM	380	68.38	49.37		58.95	50.36	
4/11/23 9:19 AM	380	68.62	49.35		59.00	50.35	
4/11/23 9:20 AM	380	68.12	49.33		58.97	50.35	
4/11/23 9:21 AM	380	68.83	49.38		58.95	50.40	
4/11/23 9:22 AM	380	68.71	49.32		59.02	50.34	
4/11/23 9:23 AM	380	68.67	49.34		58.99	50.31	
4/11/23 9:24 AM	380	68.36	49.34		58.98	50.36	
4/11/23 9:25 AM	380	68.63	49.32		58.98	50.32	
4/11/23 9:26 AM	380	68.49	49.32		58.98	50.34	
4/11/23 9:27 AM	380	68.60	49.32		58.98	50.36	
4/11/23 9:28 AM	380	68.75	49.36		58.92	50.34	
4/11/23 9:29 AM	380	68.69	49.36		58.99	50.33	
4/11/23 9:30 AM	380	68.71	49.32		59.01	50.35	
4/11/23 9:31 AM	380	68.38	49.32		58.94	50.31	
4/11/23 9:32 AM	380	68.58	49.36		58.98	50.38	
4/11/23 9:33 AM	380	68.70	49.36		59.10	50.34	
4/11/23 9:34 AM	380	68.30	49.32		58.95	50.35	
4/11/23 9:35 AM	380	68.72	49.29		58.97	50.36	
4/11/23 9:36 AM	380	68.82	49.34		59.02	50.31	
4/11/23 9:37 AM	380	68.75	49.27		59.02	50.37	
4/11/23 9:38 AM	380	68.59	49.34		59.06	50.38	
4/11/23 9:39 AM	380	68.37	49.31		58.99	50.35	
4/11/23 9:40 AM	380	68.61	49.25		58.94	50.37	
4/11/23 9:41 AM	380	68.26	49.33		59.00	50.34	
4/11/23 9:42 AM	380	68.57	49.30		59.00	50.34	
4/11/23 9:43 AM	380	68.52	49.33		58.99	50.36	
4/11/23 9:44 AM	380	68.41	49.30		58.96	50.37	
4/11/23 9:45 AM	380	68.54	49.33		59.17	50.33	
4/11/23 9:46 AM	380	68.61	49.27		59.02	50.34	
4/11/23 9:47 AM	380	68.65	49.31		59.04	50.35	
4/11/23 9:48 AM	380	68.58	49.30		58.92	50.35	
4/11/23 9:49 AM	380	68.80	49.28		59.00	50.33	
4/11/23 9:50 AM	380	68.89	49.32		58.99	50.35	
4/11/23 9:51 AM	380	68.27	49.37		58.98	50.35	
4/11/23 9:52 AM	380	68.41	49.35		58.91	50.36	
4/11/23 9:53 AM	380	68.42	49.35		58.92	50.35	
4/11/23 9:54 AM	380	68.62	49.35		58.97	50.35	
4/11/23 9:55 AM	380	68.74	49.33		59.00	50.36	
4/11/23 9:56 AM	380	68.64	49.33		59.06	50.33	
4/11/23 9:57 AM	380	68.27	49.31		59.03	50.33	
4/11/23 9:58 AM	380	68.25	49.29		58.98	50.37	
SHUTDOWN PUMP							
4/11/23 9:59 AM	0	56.72	49.31		58.35	50.34	
4/11/23 10:00 AM	0	56.78	49.23		58.46	50.35	
4/11/23 10:01 AM	0	56.71	49.31		58.45	50.36	
4/11/23 10:02 AM	0	56.72	49.35		58.42	50.35	

TEST PUMPING REPORT

95928

Ventura, IA - Deep Well

Well #4

Ventura, IA

Date: April 10, 2023

Date/Time	GPM	Well #4			Well #3		Water/Pumping Details
		PWL	Temp	Sand	SWL	Temp	
4/11/23 10:03 AM	0	56.63	49.39		58.38	50.37	
4/11/23 10:04 AM	0	56.65	49.43		58.41	50.37	
4/11/23 10:05 AM	0	56.67	49.44		58.39	50.36	
4/11/23 10:06 AM	0	56.57	49.48		58.40	50.35	
4/11/23 10:07 AM	0	56.72	49.49		58.39	50.38	
4/11/23 10:08 AM	0	56.61	49.46		58.39	50.33	
4/11/23 10:09 AM	0	56.63	49.52		58.31	50.33	
4/11/23 10:10 AM	0	56.50	49.58		58.37	50.37	
4/11/23 10:11 AM	0	56.62	49.55		58.35	50.38	
4/11/23 10:12 AM	0	56.53	49.57		58.33	50.34	
4/11/23 10:13 AM	0	56.59	49.57		58.28	50.33	
4/11/23 10:14 AM	0	56.57	49.54		58.33	50.37	
4/11/23 10:15 AM	0	56.59	49.55		58.34	50.32	
4/11/23 10:16 AM	0	56.60	49.57		58.29	50.36	
4/11/23 10:17 AM	0	56.53	49.68		58.33	50.34	
4/11/23 10:18 AM	0	56.57	49.72		58.30	50.34	
4/11/23 10:19 AM	0	56.49	49.77		58.31	50.37	
4/11/23 10:20 AM	0	56.53	49.82		58.31	50.35	
4/11/23 10:21 AM	0	56.52	49.81		58.35	50.31	
4/11/23 10:22 AM	0	56.54	49.85		58.33	50.39	
4/11/23 10:23 AM	0	56.50	49.83		58.26	50.35	
4/11/23 10:24 AM	0	56.57	49.84		58.31	50.35	
4/11/23 10:25 AM	0	56.52	49.88		58.34	50.36	
4/11/23 10:26 AM	0	56.50	49.90		58.38	50.32	
4/11/23 10:27 AM	0	56.53	49.92		58.32	50.32	
4/11/23 10:28 AM	0	56.58	49.86		58.30	50.40	
4/11/23 10:29 AM	0	56.63	49.93		58.32	50.35	
4/11/23 10:30 AM	0	56.52	50.02		58.29	50.34	