

# Northway Well and Pump Co.

4895 8th Avenue  
 Marion, Iowa 52302  
 319-377-6339  
 1-800-747-6339

100 North 6th Street  
 Waukee, Iowa 50263  
 515-987-4575  
 1-800-747-4575

## WELL TEST DATA REPORT

Customer Garden & Associates/Oskaloosa Water City Oskaloosa, Iowa  
 Location East Side of Highway 63 Well No. 36-21  
 Size Casing 24" Total Depth 53 Ft @ GL Construction Steel & SS Screen  
 Make Pump Goulds Model No. 12CHC/50hp. No. of Stages 2  
 Diameter 12" Total Setting 42 Air Line Length Electronic Sounder  
 Meter Used 6" propeller Static Level 7.2'

DATE	TIME	GPM	P.L.	D.D.	S.C.	P.S.I.	TEMP DISCHARGE DESCRIPTION
6-21-2022	8:00am	830	14.85	7.65	108.49	56	Cloudy
	8:05	830	20.65	13.45	61.71	56	Cloudy
	8:10	830	21.85	14.65	56.65	56	Clearing
	8:15	830	21.85	14.65	56.65	56	Clear
	8:20	830	21.95	14.75	56.23	56	Clear
	8:25	830	22	14.8	56.08	56	Clear
	8:30	830	22.1	14.9	55.75	56	63 Amps/Clear
	8:45	830	22.7	15.5	53.55	56	Clear
	9:00	830	23.15	15.95	52.03	56	Clear
	9:15	830	23.4	16.2	51.23	56	Clear
	9:30	830	23.55	16.35	50.76	56	Clear
	9:45	830	23.6	16.4	50.61	56	Sand Content 0ppm
	10:00	830	23.65	16.45	50.45	56	Clear
	10:30	830	23.7	16.5	50.3	56	Clear
	11:00	830	23.85	16.65	49.85	56	Clear
	11:30	830	23.85	16.65	49.85	56	Clear
	12:00pm	830	23.9	16.7	49.7	56	Clear
	12:30	830	24.05	16.85	49.26	56	Clear
	1:00	830	24.1	16.9	49.11	56	Clear
	1:30	830	24.1	16.9	49.11	56	Clear
	2:00	830	24.15	16.95	48.96	56	Clear
	2:30	830	24.15	16.95	48.96	56	Clear
	3:00	830	24.1	16.9	49.11	56	Clear
	3:30	830	24.2	17	48.82	56	Clear
	4:00	830	24.25	17.05	48.68	56	Clear
	4:30	830	24.25	17.05	48.68	56	Clear
	5:00	830	24.35	17.15	48.39	56	Clear
	5:30	830	24.4	17.3	48.25	57	Clear

Note: All water level measurements are from ground level  
 The discharge hose was 100 feet from Well.

# Northway Well and Pump Co.

4895 8th Avenue  
 Marion, Iowa 52302  
 319-377-6339  
 1-800-747-6339

100 North 6th Street  
 Waukee, Iowa 50263  
 515-987-4575  
 1-800-747-4575

## WELL TEST DATA REPORT

PAGE -2-

Customer Garden & Associates/Oskaloosa Water City Oskaloosa, Iowa  
 Location East Side of Highway 63 Well No. 36-21

DATE	TIME	GPM	P.L.	D.D.	S.C.	P.S.I.	TEMP DISCHARGE DESCRIPTION
6-21-2022	6:00pm	830	24.5	17.3	47.97	56	54° Clear
	6:30	830	24.5	17.3	47.97	56	Sand Content 0ppm
	7:00	830	24.4	17.3	48.25	56	Clear
	7:30	830	24.2	17	48.82	56	Clear
	8:00	830	24.1	16.9	49.11	56	Clear
	8:30	830	24.1	16.9	49.11	56	Clear
	9:00	830	24	16.8	49.4	56	Clear
	9:30	830	24.1	16.9	49.11	56	Clear
	10:00	830	24.1	16.9	49.11	56	Clear
	10:30	830	24.1	16.9	49.11	56	Clear
	11:00	830	24.3	17.1	48.54	56	Clear
	11:30	830	24.4	17.2	48.25	56	Clear
6-22-2022	12:00am	830	24.5	17.3	47.93	56	Sand Content 0ppm
	12:30	830	24.5	17.3	47.97	56	Clear
	1:00	830	24.6	17.4	47.7	56	Clear
	1:30	830	24.6	17.4	47.7	56	Clear
	2:00	830	24.6	17.4	47.7	56	Clear
	2:30	830	24.6	17.4	47.7	56	Clear
	3:00	830	24.5	17.3	47.97	56	Clear
	3:30	830	24.45	17.25	48.11	56	Clear
	4:00	830	24.35	17.15	48.39	56	Clear
	4:30	830	24.25	17.05	48.68	56	Clear
	5:00	830	24.25	17.05	48.68	56	Clear
	5:30	830	24.25	17.05	48.68	56	Clear
	6:00	830	24.15	16.95	48.96	56	Clear
	6:30	830	24.15	16.95	48.96	56	Clear
	7:00	830	24.2	17	48.82	56	Clear
	7:30	830	24.1	16.9	49.11	56	Sand Content 0ppm
	8:00	830	24.1	16.9	49.11	56	Clear
	8:30	830	24.1	16.9	49.11	56	Clear

9:00 pump was shut off

Note: It appears these Well's have possibly a slight influence by the near by Well's during operation.

