

LATTA WELL & PUMP CORP

City of Wilton

August 17, 2022

Pump Test

Time	Water Level	
10:00am	28'	Pump on 18' @ 770gpm
1 minute	30'	
2 min	30'	
3 min	31'	
4 min	31'	
5 min	32'	
10 min	32' 3"	
15 min	32' 4"	
20 min	32' 5"	
25 min	32' 6"	
30 min	32' 7"	
45 min	32' 8"	
1 hour	32' 9"	
1 hr 30 min	32' 9"	
2 hours	32' 8"	
3 hours	32' 10"	Samples taken
5 hours	32' 9"	
6 hours	32' 9"	
7 hours	32' 9"	
8 hours	32' 9"	
9 hours	32' 9"	
10 hours	32' 9"	
11 hours	32' 9"	
12 hours	32' 9"	
10:00pm	32' 9"	Pump off
10:01pm	24'	
2 min	22' 6"	
3 min	21' 6"	
4 min	21' 4"	
5 min	21' 3"	
10 min	21'	
20 min	20' 10"	
30 min	20' 9"	
45 min	20' 7"	
1 hour	20' 6"	
2 hr	19' 11"	
3 hr	19' 1"	
4 hr	18' 3"	
5 hr	18' 1"	test Over