WELL TEST DATA REPORT

NORTHWAY WELL AND PUMP COMPANY

4895- 8th Avenue, Marion, IA 52302
319-377-6339

100 North 6th Street, Wanker, IA 50263
515-987-4575

Customer Water Works City Greene, Iowa Location Next to high school

Well No. 1 Size of Casing 8" Total Depth 205' Construction Limestone

Pump Make Simmons Model No. _____ No. of Stages 4 Diameter 6"

Total Setting 147' Air Line Length 147' Meter Used 4" Prop Static Level 25'

DATE	TIME	GPM	P.L.	D.D.	S.C.	PSI	DISCHARG DESCRIPTION
12-3-97	2:00	200	29'	4	50	20	Turbid
	2:15	200	29'	4	50	20	Turbid
	2:30	200	29'	4	50	20	Turbid
	2:45	200	29'	4	50	20	Dirty
	3:00	300	29'4"	4.4	68.18	10	Dirty
	3:15	200	29'4"	4.4	68.18	10	Cloudy
	3:30	300	29'4"	4.4	68.18	10	Cloudy
	3:45	350	29'7"	4.7	74.4	5	Cloudy
	4:00	350	29'7"	4.7	74.4	5	Cloudy
	4:15	350	29'7"	4.7	74.4	5	Clearing
	4:30	350	29'7"	4.7	74.4	5	Clearing
	4:45	350	29'7"	4.7	74.4	5	Clear
	5:00	350	29'7"	4.7	74.4	5	Clear
Recovery	5:05	0	26'3"				
	5:10	0	25'8"				
	5:15	0	25'4"				
	5:20	0	25'2"				
	5:30	0	25'.0	Static	Level		